



Rules of
Department of Natural Resources
Division 26—Petroleum and Hazardous Substance
Storage Tanks
Chapter 2—Underground Storage Tanks—
Technical Regulations

Title		Page
10 CSR 26-2.010	Applicability	3
10 CSR 26-2.011	Interim Prohibition for Deferred Underground Storage Tank Systems	3
10 CSR 26-2.012	Definitions	3
10 CSR 26-2.019	New Installation Requirements	5
10 CSR 26-2.020	Performance Standards for New Underground Storage Tank Systems.....	6
10 CSR 26-2.021	Upgrading of Existing Underground Storage Tank Systems.....	8
10 CSR 26-2.022	Notification Requirements.....	9
10 CSR 26-2.030	Spill and Overfill Control.....	10
10 CSR 26-2.031	Operation and Maintenance of Corrosion Protection	10
10 CSR 26-2.032	Compatibility	11
10 CSR 26-2.033	Repairs Allowed	11
10 CSR 26-2.034	Reporting and Record Keeping	12
10 CSR 26-2.040	General Requirements for Release Detection for All Underground Storage Tank Systems.....	13
10 CSR 26-2.041	Requirements for Petroleum Underground Storage Tank Systems	13
10 CSR 26-2.042	Requirements for Hazardous Substance Underground Storage Tank Systems	14
10 CSR 26-2.043	Methods of Release Detection for Tanks	14
10 CSR 26-2.044	Methods of Release Detection for Piping	16
10 CSR 26-2.045	Release Detection Record Keeping.....	17
10 CSR 26-2.050	Reporting of Suspected Releases	17



10 CSR 26-2.051	Investigation Due to Off-Site Impacts	17
10 CSR 26-2.052	Release Investigation and Confirmation Steps	17
10 CSR 26-2.053	Reporting and Cleanup of Spills and Overfills	18
10 CSR 26-2.060	Taking USTs Out of Use	18
10 CSR 26-2.061	Permanent Closure and Changes in Service	19
10 CSR 26-2.062	Assessing the Site at Closure or Change in Service.....	19
10 CSR 26-2.063	Applicability to Previously Closed Underground Storage Tank Systems	20
10 CSR 26-2.064	Closure Records	20
10 CSR 26-2.070	Release Response and Corrective Action.....	20
10 CSR 26-2.071	Initial Release Response and Corrective Action	20
10 CSR 26-2.072	Initial Abatement Measures and Investigation.....	21
10 CSR 26-2.074	Initial Site Characterization.....	21
10 CSR 26-2.075	Free-Product Removal	21
10 CSR 26-2.078	Investigations for Soil and Groundwater Cleanup	22
10 CSR 26-2.080	Risk-Based Target Levels	22
10 CSR 26-2.082	Corrective Action Plan	23
10 CSR 26-2.083	Public Participation	24



**Title 10—DEPARTMENT OF
NATURAL RESOURCES**
**Division 26—Petroleum and Hazardous
Substance Storage Tanks**
**Chapter 2—Underground Storage
Tanks—Technical Regulations**

10 CSR 26-2.010 Applicability

PURPOSE: This rule defines the underground storage tanks that are subject to the requirements of this chapter. This rule contains the technical standards for underground storage tanks. This rule is designed specifically to protect the quality of groundwater in the state as well as to protect human health and the overall quality of the environment. This rule is promulgated on the authority of sections 319.100–319.137, RSMo, and, as directed by this law, are based upon federal rules 40 CFR 280.10–40 CFR 280.74.

(1) The requirements of this chapter apply to all owners and operators of an underground storage tank (UST) system as defined in 10 CSR 26-2.012, except as otherwise provided in sections (2)–(4) of this rule. Any UST system listed in section (3) of this rule must meet the requirements of 10 CSR 26-2.011.

(2) The following UST systems are excluded from the requirements of this chapter:

(A) Any UST system holding hazardous wastes listed or identified in the Missouri Hazardous Waste Management Law, sections 260.350–260.434, RSMo, and the rules promulgated thereunder or a mixture of hazardous waste and other regulated substances, except for waste oil as defined in 10 CSR 25-11.279;

(B) Any wastewater treatment tank system that is part of a wastewater treatment facility regulated under Section 402 or 307(b) of the Clean Water Act (33 U.S.C. 1251);

(C) Equipment or machinery that contains regulated substances for operational purposes such as hydraulic lift tanks and electrical equipment tanks;

(D) Any UST system whose capacity is one hundred ten (110) gallons or less;

(E) Any UST system that is installed within a vault, if all exterior surface areas of the tank may be visually inspected without removal of backfill, gravel, sand, or other fill material;

(F) Any UST system that contains a *de minimis* concentration of regulated substances; and

(G) Any emergency spill or overflow containment UST system that is expeditiously emptied after use.

(3) Deferrals. Rules 10 CSR 26-2.020–10 CSR 26-2.053 and closure requirements in 10 CSR 26-2.060–10 CSR 26-2.064 do not apply to any of the following types of UST systems:

(A) Wastewater treatment tank systems;

(B) Any UST systems containing radioactive material that are regulated under the Atomic Energy Act of 1954 (42 U.S.C. 2011 and following);

(C) Any UST system that is part of an emergency generator system at nuclear power generation facilities regulated by the Nuclear Regulatory Commission under 10 CFR 50, Appendix A;

(D) Airport hydrant fuel distribution systems; and

(E) UST systems with field-constructed tanks.

AUTHORITY: sections 319.100, 319.105, 319.107, 319.111, and 319.114, RSMo 2000, and sections 319.109 and 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.010. Original rule filed April 2, 1990, effective Sept. 28, 1990. Amended: Filed Jan. 2, 1996, effective Aug. 30, 1996. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.100, RSMo 1989, amended 1991, 1993, 1996, 1998; 319.105, RSMo 1989; 319.107, RSMo 1989, amended 1994; 319.109, RSMo 1989, amended 1995, 2004, 2008; 319.111, RSMo 1989; 319.114, RSMo 1989; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.011 Interim Prohibition for Deferred Underground Storage Tank Systems

PURPOSE: This rule establishes minimum performance standards for the installation of deferred underground storage tanks.

PUBLISHER'S NOTE: The secretary of state has determined that the publication of the entire text of the material which is incorporated by reference as a portion of this rule would be unduly cumbersome or expensive. This material as incorporated by reference in this rule shall be maintained by the agency at its headquarters and shall be made available to the public for inspection and copying at no more than the actual cost of reproduction. This note applies only to the reference material. The entire text of the rule is printed here.

(1) No person may install an underground storage tank (UST) system listed in 10 CSR 26-2.010(3) for the purpose of storing regulated substances unless the UST system

(whether of single- or double-wall construction)—

(A) Will prevent releases due to corrosion or structural failure for the operational life of the UST system;

(B) Is cathodically protected against corrosion, constructed of noncorrodible material, steel-clad with a noncorrodible material, or designed in a manner to prevent the release or threatened release of any stored substance; and

(C) Is constructed or lined with material that is compatible with the stored substance.

(2) Notwithstanding section (1) of this rule, a UST system without corrosion protection may be installed at a site that is determined by a corrosion expert not to be corrosive enough to cause it to have a release due to corrosion during its operating life. Owners and operators must maintain records that demonstrate compliance with the requirements of this section for the remaining life of the tank.

(3) The determination in section (2) of this rule should comply with the following recommended practice: NACE International RP 0285-2002, *Corrosion Control of Underground Storage Tank Systems by Cathodic Protection*, revised 2002. This document is incorporated by reference without any later amendments or modifications. To obtain a copy contact NACE International, Box 218340, Houston, TX 77218-8340, (713) 492-0535, www.nace.org.

AUTHORITY: section 319.105, RSMo 2000 and section 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.011. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.105, RSMo 1989 and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.012 Definitions

PURPOSE: This rule defines specific words used in this chapter.

PUBLISHER'S NOTE: The secretary of state has determined that the publication of the entire text of the material which is incorporated by reference as a portion of this rule would be unduly cumbersome or expensive. This material as incorporated by reference in this rule shall be maintained by the agency at its headquarters and shall be made available to the public for inspection and copying at no more than the actual cost of reproduction.



This note applies only to the reference material. The entire text of the rule is printed here.

(1) Many definitions relevant to this rule are set forth in the underground storage tank law in section 319.100, RSMo. The regulations set forth in 40 CFR part 280.12, July 1, 2010, as published by the Office of the Federal Register, National Archives and Records Administration, Superintendent of Documents, Pittsburgh, PA 15250-7954, are incorporated by reference. This rule does not incorporate any subsequent amendments or additions. The definitions set forth in 40 CFR 280.12, are subject to the following additions, modifications, substitutions, or deletions in the subsections:

(A) Definitions beginning with the letter A.

1. "Annual" means recurring, done, or performed every three hundred sixty-five (365) days.

2. "Annually" means at least once every three hundred sixty-five (365) days;

(B) Definitions beginning with the letter B. (Reserved);

(C) Definitions beginning with the letter C.

1. To the definition of "CERCLA" at 40 CFR 280.12, incorporated in this rule, add the words "by the Superfund Amendments and Reauthorization Act of 1986" after the words "as amended";

(D) Definitions beginning with the letter D.

1. "*De minimus*" means—

A. Any volume of regulated substance(s) contained in a tank with a capacity of less than one hundred ten (110) gallons; or

B. A very low concentration of regulated substances; or

C. Any volume of regulated substance(s) contained in an emergency backup tank that holds regulated substances for only a short period of time and is expeditiously emptied after use. (Comment: *De minimus* tanks include: swimming pools, permitted wastewater treatment facilities, and chlorinated, potable water storage tanks. An oil-water separator is not a *de minimus* system unless the tank has a less than one hundred ten (110) gallon capacity.)

2. "Department," unless otherwise stated, means the Missouri Department of Natural Resources;

(E) Definitions beginning with the letter E.

1. In the definition for "existing tank system" in 40 CFR 280.12 incorporated in this rule, substitute the date "September 28, 1990" for the date "December 22, 1988";

(F) Definitions beginning with the letter F. (Reserved);

(G) Definitions beginning with the letter G. (Reserved);

(H) Definitions beginning with the letter H.

1. This definition shall apply in lieu of the definition of "hazardous substance UST system" in 40 CFR 280.12 incorporated in this rule. "Hazardous substance UST system" means a UST system that contains a hazardous substance defined in Section 101(14) of the CERCLA (but not including any substance regulated as a hazardous waste under the Missouri Hazardous Waste Management Law, sections 260.350–260.434, RSMo) or any mixture of these substances and petroleum, and which is not a petroleum UST system;

(I) Definitions beginning with the letter I.

1. The definition for "implementing agency" in 40 CFR 280.12 is not incorporated into this rule.

2. The term "in-operation" means input or output that occurs on a regular basis for the tank's intended purpose.

3. The terms "in-service" and "in-use" are equivalent and mean that the tank system contains more than one inch (1") of a regulated substance or residue or three-tenths percent (0.3%) by weight of the total capacity of the UST system of regulated substance. A tank is considered to be in-service and in-use beginning with the first input of a regulated substance into the tank system.

4. The term "installer" means any person, partnership, corporation, company, business, firm, society, or association that installs part or all of an underground storage tank system;

(J) Definitions beginning with the letter J. (Reserved);

(K) Definitions beginning with the letter K. (Reserved);

(L) Definitions beginning with the letter L. (Reserved);

(M) Definitions beginning with the letter M.

1. "Month," unless otherwise stated, means thirty (30) days.

2. "Monthly" means at least once every thirty (30) days;

(N) Definitions beginning with the letter N.

1. In the definition for "new tank system" in 40 CFR 280.12 incorporated in this rule, substitute the date "September 28, 1990" for the date "December 22, 1988";

(O) Definitions beginning with the letter O.

1. In the definition for "operational life" in 40 CFR 280.12 incorporated in this rule,

substitute "10 CSR 26-2.060–10 CSR 26-2.064" for "Subpart G."

2. The terms "out-of-service" and "out-of-use" are equivalent and mean that the tank system has been emptied so that no more than one inch (1") of regulated substance or residue or three-tenths percent (0.3%) by weight of the total capacity of the UST system remains.

3. The definition for "owner" in 40 CFR 280.12 is not incorporated in this rule, and the definition in section 319.100(9), RSMo, shall be used instead;

(P) Definitions beginning with the letter P.

1. The definition for "person" in 40 CFR 280.12 is not incorporated in this rule and the definition in section 319.100(11), RSMo, shall be used instead;

(Q) Definitions beginning with the letter Q. (Reserved);

(R) Definitions beginning with the letter R.

1. The definition for "regulated substance" in 40 CFR 280.12 is not incorporated in this rule, and the definition in section 319.100(14), RSMo, shall be used instead.

2. The definition for "release" in 40 CFR 280.12 is not incorporated in this rule, and the definition in section 319.100(15), RSMo, shall be used instead.

3. "Routinely contains regulated substance" means that a regulated substance regularly passes through the piping, but does not necessarily mean that the piping must continuously hold a regulated substance. Satellite lines, gravity piping, and remote fill lines, including lines from aboveground storage tank(s) to underground storage tank(s), all routinely contain a regulated substance. Vapor lines, including vent lines and vapor recovery lines, are not included;

(S) Definitions beginning with the letter S.

1. In lieu of the definition for "septic tank" in 40 CFR 280.12, the definition for "septic tank" shall be any watertight, covered receptacle designed and constructed to receive the discharge of sewage, separate solids from liquid, digest organic matter, store liquids through a period of detention, and allow the clarified liquids to discharge to a soil treatment system;

(T) Definitions beginning with the letter T.

1. "Triennial" means recurring, done, or performed every one thousand ninety-five (1,095) days.

2. "Triennially" means at least once every one thousand ninety-five (1,095) days.

(U) Definitions beginning with the letter U.

1. In the definition of "upgrade" in 40 CFR 280.12 incorporated in this rule, substitute the words "regulated substance" for the word "product."



2. The definition for “underground storage tank” or “UST” found in 40 CFR 280.12 is not incorporated in this rule, and the definition in section 319.100(16), RSMo, shall be used instead;

(V) Definitions beginning with the letter V. (*Reserved*);

(W) Definitions beginning with the letter W. (*Reserved*);

(X) Definitions beginning with the letter X. (*Reserved*);

(Y) Definitions beginning with the letter Y. (*Reserved*);

(Z) Definitions beginning with the letter Z. (*Reserved*).

AUTHORITY: sections 319.100, 319.105, 319.107, 319.111, and 319.114, RSMo 2000, and sections 319.109 and 319.137, RSMo Supp. 2010. * This rule originally filed as 10 CSR 20-10.012. Original rule filed April 2, 1990, effective Sept. 28, 1990. Amended: Filed Dec. 31, 1991, effective Aug. 6, 1992. Amended: Filed Jan. 2, 1996, effective Aug. 30, 1996. Amended: Filed Jan. 14, 1997, effective Sept. 30, 1997. Amended: Filed April 1, 1999, effective March 30, 2000. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.

*Original authority: 319.100, RSMo 1989, amended 1991, 1993, 1996, 1998; 319.105, RSMo 1989; 319.107, RSMo 1989, amended 1994; 319.109, RSMo 1989, amended 1995, 2004, 2008; 319.111, RSMo 1989; 319.114, RSMo 1989; 319.132, RSMo 1991, amended 1995, 1996, 1998; and 319.137, RSMo 1989, amended 1993, 1995, 2004.

10 CSR 26-2.019 New Installation Requirements

PURPOSE: This rule sets the standards that installations and installers of new underground storage tank systems must meet.

PUBLISHER’S NOTE: The secretary of state has determined that the publication of the entire text of the material which is incorporated by reference as a portion of this rule would be unduly cumbersome or expensive. This material as incorporated by reference in this rule shall be maintained by the agency at its headquarters and shall be made available to the public for inspection and copying at no more than the actual cost of reproduction. This note applies only to the reference material. The entire text of the rule is printed here.

(1) Any installer who intends to install an underground storage tank (UST) system for storage of a regulated substance must, at least thirty (30) days before installing the tank, notify the department by letter or approved

form transmitted via email of intent to install an UST, except that this thirty (30) day notice requirement may be waived by the department when a release is suspected or in other similarly urgent circumstances. The notification must provide the tank owner’s name, installer name, the name and location of the facility where the UST will be installed, the date that the installation is expected to commence, the date that the tank is expected to be brought in-use, UST system information, including tank material, size, manufacturer, piping material, piping type, and manufacturer, release detection equipment, and spill and overfill equipment. The installation notice is valid for one hundred eighty (180) days from receipt by the department and only for the UST system(s) listed on the notice. If installation does not commence within one hundred eighty (180) days of the date on which the department received the notice, a new installation notice must be submitted prior to commencing installation activities.

(2) Installers must document compliance with all manufacturer certification or training requirements for tank, piping, release detection equipment, and spill and overfill equipment installed.

(3) Installers and manufacturers must be properly registered with the Missouri Department of Agriculture and have a current financial responsibility mechanism that complies with the requirements of 2 CSR 90-30.085.

(4) Prior to installation of an UST intended to be used for storage of a regulated substance, the tank and associated piping must be tested, inspected, and measured in accordance with the manufacturer’s requirements and in accordance with the pre-installation inspection, testing, and/or backfilling sections of either—

(A) American Petroleum Institute’s Recommended Practice 1615, *Installation of Underground Petroleum Storage Systems*, fifth edition, 2011. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the American Petroleum Institute, 1220 L Street NW, Washington, DC 20005, (202) 682-8000, www.api.org/standards/; or

(B) Petroleum Equipment Institute’s Recommended Practice 100-2011, *Installation of Underground Liquid Storage Systems*, 2011 edition. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the Petroleum Equipment Institute, Box 2380, Tulsa, OK 74101-2380, (918) 494-9696, www.pei.org.

(5) Tanks, piping, and equipment must comply with the new system requirements in 10 CSR 26-2.020. Installations shall be conducted in accordance with all manufacturers’ requirements and in accordance with either—

(A) American Petroleum Institute’s Recommended Practice 1615, *Installation of Underground Petroleum Storage Systems*, fifth edition, 2011. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the American Petroleum Institute, 1220 L Street NW, Washington, DC 20005, (202) 682-8000, www.api.org/standards/; or

(B) Petroleum Equipment Institute’s Recommended Practice 100-2011, *Installation of Underground Liquid Storage Systems*, 2011 edition. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the Petroleum Equipment Institute, Box 2380, Tulsa, OK 74101-2380, (918) 494-9696, www.pei.org.

(6) Should one (1) or more of a manufacturer’s requirements contradict the recommended industry practice(s), the manufacturer’s requirements shall be followed. Backfill materials must meet tank and piping manufacturers’ specifications.

(7) The tank and piping system must pass a 0.1 gallon/hour system tightness test before the system is brought in operation.

(8) Until the installation is complete and the system is released by the installer to the owner/operator, the tank shall be monitored for leaks daily by using either—

(A) An approved release detection method, in accordance with 10 CSR 26-2.043; or

(B) Daily Inventory Liquid Measurements. Upon completion of initial post-installation tightness testing, daily measurements are based on the average of two (2) consecutive stick readings. A variation of no greater than twenty-six (26) gallons per week is allowed. Any suspected release, alarm, or inconclusive or failure result from these release detection methods must be reported and investigated in accordance with 10 CSR 26-2.050.

(9) Upon the department’s discovery of an installation that is not in compliance with the requirements of this rule, the department’s authorized representative may require that the installation remain open and uncovered, or that no additional UST system work be conducted, until—

(A) The manufacturer approves the installation that deviates from their written guidelines, specifications, and instructions;



(B) The owner approves the installation; and

(C) The department approves the installation.

(10) Any equipment repairs necessary during the installation must be manufacturer certified or approved, with supporting written documentation from the manufacturer.

(11) Certification of Installation. All installers must ensure that one (1) or more of the following methods of certification, testing or inspection is used to demonstrate compliance with this rule by providing a certification of compliance:

(A) The installation has been inspected and approved by the department;

(B) All work listed in the manufacturer's installation checklists has been completed and submitted to the department; or

(C) The installer has complied with another method for ensuring compliance with this rule that is determined by the department to be no less protective of human health and the environment.

AUTHORITY: sections 319.105, RSMo 2000. Original rule filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.105, RSMo 1989.*

10 CSR 26-2.020 Performance Standards for New Underground Storage Tank Systems

PURPOSE: This rule sets the standards for tanks, piping, spill and overflow prevention equipment, installation, and certification of installation that new underground storage tanks must meet.

PUBLISHER'S NOTE: The secretary of state has determined that the publication of the entire text of the material which is incorporated by reference as a portion of this rule would be unduly cumbersome or expensive. This material as incorporated by reference in this rule shall be maintained by the agency at its headquarters and shall be made available to the public for inspection and copying at no more than the actual cost of reproduction. This note applies only to the reference material. The entire text of the rule is printed here.

(1) In order to prevent releases due to structural failure, corrosion, or spills and overfills for as long as the underground storage tank (UST) system is used to store regulated substances, all owners and operators of new UST

systems must meet the following requirements:

(A) Tanks. Each tank must be properly designed and constructed, and any portion underground that routinely contains a regulated substance must be protected from corrosion, in accordance with a code of practice developed by a nationally-recognized association or independent testing laboratory as follows:

1. The tank is constructed of fiberglass-reinforced plastic and complies with—

A. Underwriters' Laboratories Standard 1316, *Standard for Glass-Fiber-Reinforced Plastic Underground Storage Tanks for Petroleum Products, Alcohol and Alcohol-Gasoline Mixtures*, revised 2006. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the Underwriters' Laboratories, 333 Pfingsten Road, Northbrook, IL 60062-2096, (847) 272-8800, www.ul.com; or

B. Other standards or publications approved by the department; or

2. The tank is constructed of steel and cathodically protected in the following manner:

A. The tank is coated with a suitable dielectric material;

B. Field-installed cathodic protection systems are designed by a corrosion expert;

C. Impressed current systems are designed to allow determination of current operating status as required in 10 CSR 26-2.031(1)(C);

D. Cathodic protection systems are operated and maintained in accordance with 10 CSR 26-2.031 or according to guidelines established by the department; and

E. The following codes and standards may be used to comply with paragraph (1)(A)2. of this rule:

(I) Steel Tank Institute *Specification for STI-P3 System of External Corrosion Protection of Underground Steel Storage Tanks*, revised 2010. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the Steel Tank Institute, 944 Donata Court, Lake Zurich, IL 60047, (708) 438-8265, www.steel-tank.com;

(II) Underwriters' Laboratories Standard 1746, *Standard for External Corrosion Protection Systems for Steel Underground Storage Tanks*, revised 2007. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the Underwriters' Laboratories, 333 Pfingsten Road, Northbrook, IL 60062-2096, (847) 272-8800, www.ul.com;

(III) NACE International RP 0285-2002, *Corrosion Control of Underground Storage Tank Systems by Cathodic Protection*, revised 2002. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact NACE International, Box 218340, Houston, TX 77218-8340, (713) 492-0535, www.nace.org;

(IV) Underwriters' Laboratories Standard 58, *Standard for Steel Underground Tanks for Flammable and Combustible Liquids*, revised 1998. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the Underwriters' Laboratories, 333 Pfingsten Road, Northbrook, IL 60062-2096, (847) 272-8800, www.ul.com; or

3. The tank is a composite tank with a steel inner tank and a non-metallic external thick film coating or the tank is a steel inner tank constructed with a non-metallic external jacket forming a secondary wall. Either of these tanks shall comply with one (1) of the following industry codes:

A. Underwriters' Laboratories Standard 1746, *Standard for External Corrosion Protection Systems for Steel Underground Storage Tanks*, revised 2007. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the Underwriters' Laboratories, 333 Pfingsten Road, Northbrook, IL 60062-2096, (847) 272-8800, www.ul.com;

B. Steel Tank Institute's ACT-100, *Specification for External Corrosion Protection of FRP Composite Steel USTs (F894)*, revised June 2010. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the Steel Tank Institute, 944 Donata Court, Lake Zurich, IL 60047, (708) 438-8265, www.steel-tank.com;

C. Underwriters' Laboratories Standard 58, *Standard for Safety for Steel Underground Storage Tanks for Flammable and Combustible Liquids*, revised 1998. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the Underwriters' Laboratories, 333 Pfingsten Road, Northbrook, IL 60062-2096, (847) 272-8800, www.ul.com; or

D. Steel Tank Institute's ACT-100-U, *Specification for External Corrosion Protection of Composite Steel Underground Storage Tanks*, F961, June 2010. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the Steel Tank Institute,



944 Donata Court, Lake Zurich, IL 60047, (708) 438-8265, www.steeltank.com; or

4. The tank is constructed of metal without additional corrosion protection measures provided that—

A. The tank is installed at a site that is determined by a corrosion expert not to be corrosive enough to cause it to have a release due to corrosion during its operating life; and

B. Owners and operators maintain records that demonstrate compliance with the requirements of subparagraph (1)(B)4.A. of this rule for the remaining life of the tank; or

5. The tank construction and corrosion protection are determined by the department to be designed to prevent the release or threatened release of any stored regulated substance in a manner that is no less protective of human health and the environment than paragraphs (1)(A)1.-4. of this rule;

(B) Piping. The piping that routinely contains regulated substances and is in contact with an electrolyte, including but not limited to soil, backfill, and/or water, must be properly designed, constructed, and protected from corrosion in accordance with a code of practice developed by a nationally-recognized association or independent testing laboratory as follows:

1. The piping is constructed of fiberglass-reinforced plastic;

2. The following codes and standards may be used to comply with paragraph (1)(B)1. of this rule:

A. Underwriters' Laboratories Standard 971, *UL Listed Nonmetallic Underground Piping for Flammable Liquids*, revised 2006. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the Underwriters' Laboratories, 333 Pfingsten Road, Northbrook, IL 60062-2096, (847) 272-8800, www.ul.com; and

B. Underwriters' Laboratories Standard 567, *Emergency Breakaway Fittings, Swivel Connectors and Pipe Connection Fittings for Petroleum Products and LP-Gas*, revised 2003. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the Underwriters' Laboratories, 333 Pfingsten Road, Northbrook, IL 60062-2096, (847) 272-8800, www.ul.com;

3. The piping is constructed of steel and cathodically protected in the following manner:

A. The piping is coated with a suitable dielectric material;

B. Field-installed cathodic protection systems are designed by a corrosion expert;

C. Impressed current systems are designed to allow determination of current

operating status as required in 10 CSR 26-2.031(1)(C);

D. Cathodic protection systems are operated and maintained in accordance with 10 CSR 26-2.031; and

E. The following codes and standards may be used to comply with paragraph (1)(B)3. of this rule:

(I) National Fire Protection Association Standard 30, *Flammable and Combustible Liquids Code*, revised 2008. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the National Fire Protection Association, 1 Batterymarch Park, Box 9101, Quincy, MA 02269-9101, (617) 770-3000, www.nfpa.org;

(II) American Petroleum Institute's Recommended Practice 1615, *Installation of Underground Petroleum Storage Systems*, fifth edition, 2011. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the American Petroleum Institute, 1220 L Street NW, Washington, DC 20005, (202) 682-8000, www.api.org/standards/;

(III) American Petroleum Institute Publication 1632, *Cathodic Protection of Underground Petroleum Storage Tanks and Piping Systems*, revised 2002. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the American Petroleum Institute, 1220 L Street NW, Washington, DC 20005, (202) 682-8000, www.api.org/standards/;

(IV) NACE International SP-0169-2007, *Control of External Corrosion on Submerged Metallic Piping Systems*, revised 2007. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact NACE International, Box 218340, Houston, TX 77218-8340, (713) 492-0535, www.nace.org; and

(V) Steel Tank Institute's *Recommended Practice for Corrosion Protection of Underground Piping Networks Associated with Liquid Storage and Dispensing Systems* (R892), revised 2006. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the Steel Tank Institute, 944 Donata Court, Lake Zurich, IL 60047, (708) 438-8265, www.steeltank.com;

4. The piping is constructed of metal without additional corrosion protection measures provided that—

A. The piping is installed at a site that is determined by a corrosion expert to not be corrosive enough to cause it to have a release due to corrosion during its operating life; and

B. Owners and operators maintain records that demonstrate compliance with the requirements of subparagraph (1)(A)4.A. of this rule for the remaining life of the tank;

5. The following codes may be used to comply with paragraph (1)(B)4. of this rule:

A. National Fire Protection Association Standard 30, *Flammable and Combustible Liquids Code*, revised 2008. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the National Fire Protection Association, 1 Batterymarch Park, Box 9101, Quincy, MA 02269-9101, (617) 770-3000, www.nfpa.org; and

B. NACE International SP-0169-2007, *Control of External Corrosion on Submerged Metallic Piping Systems*, revised 2007. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact NACE International, Box 218340, Houston, TX 77218-8340, (713) 492-0535, www.nace.org; or

6. The piping construction and corrosion protection are determined by the department to be designed to prevent the release or threatened release of any stored regulated substance in a manner that is no less protective of human health and the environment than the requirements in paragraphs (1)(B)1.-5. of this rule;

(C) Spill and Overfill Prevention Equipment.

1. Except as provided in paragraph (1)(C)2. of this rule, to prevent spilling and overfilling associated with product transfer to the UST system, owners and operators must use the following spill and overfill prevention equipment:

A. Spill prevention equipment that will prevent release of product to the environment when the transfer hose is detached from the fill pipe (for example, a spill catchment basin). All delivery hose-fill pipe connections must be tight, lock-on connections; and

B. Overfill prevention equipment that will—

(I) Automatically shut off flow into the tank when the tank is no more than ninety-five percent (95%) full;

(II) Alert the operator with a high-level alarm at least one (1) minute before overfilling with an alarm audible in the delivery area; or

(III) Alert the transfer operator when the tank is no more than ninety percent (90%) full by restricting flow into the tank.

(a) Ball float valves may only be used in tank systems with gravity deliveries, in suction systems if there are no check



valves, except those contained within a building, and the tank system is tight so that it does not allow vapors to be released during a delivery after the ball float valve has closed.

(b) Ball float valves are not approved for use as overflow prevention equipment in new tank systems installed after December 31, 2011. Ball float valves may still be used in systems equipped with manifolded vent lines and vapor recovery equipment if the ball float valve is installed no lower than at ninety-eight percent (98%) full and the functioning overflow prevention equipment is installed no higher than ninety-five percent (95%) full.

(IV) For pressurized deliveries, overflow prevention equipment must be compatible and approved for use with pressurized deliveries.

2. Owners and operators are not required to use the spill and overflow prevention equipment specified in paragraph (1)(C)1. of this rule if—

A. Alternative equipment is used that is determined by the department to be no less protective of human health and the environment than the equipment specified in subparagraph (1)(C)1.A. or B. of this rule; or

B. The owner or operator submits a written explanation that the equipment cannot be used for the UST system and their detailed fuel-delivery plan, documenting that their delivery procedures prevent spills and overfills; or

C. The UST system is filled by transfers of no more than twenty-five (25) gallons at one time.

(D) All new tank systems installed after December 31, 2011, must be installed with containment sumps at each tank top suction piping or submersible turbine pump connection, each piping transition/ball valve location, and under each dispenser. The containment sumps must be designed to contain any leak from the primary UST piping system; and

(E) Installation. All tanks and piping must be properly installed in accordance with a code of practice developed by a nationally-recognized association or independent testing laboratory, in accordance with all manufacturers' instructions, and in accordance with 10 CSR 26-2.019. Tank and piping system installation practices and procedures described in the following codes may be used to comply with the requirements of this rule:

1. American Petroleum Institute Publication 1615, *Installation of Underground Petroleum Storage System*, revised 2011. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the American

Petroleum Institute, 1220 L Street NW, Washington, DC 20005, (202) 682-8000, www.api.org/standards/; or

2. Petroleum Equipment Institute Publication RP100, *Recommended Practices for Installation of Underground Liquid Storage Systems*, revised 2011. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the Petroleum Equipment Institute, Box 2380, Tulsa, OK 74101-2380, (918) 494-9696, www.pei.org.

AUTHORITY: sections 319.105 and 319.107, RSMo 2000, and section 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.020. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.105, RSMo 1989; 319.107, RSMo 1989, amended 1994; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.021 Upgrading of Existing Underground Storage Tank Systems

PURPOSE: This rule contains the options for upgrading existing underground storage tanks for continued operation after December 22, 1998.

PUBLISHER'S NOTE: The secretary of state has determined that the publication of the entire text of the material which is incorporated by reference as a portion of this rule would be unduly cumbersome or expensive. This material as incorporated by reference in this rule shall be maintained by the agency at its headquarters and shall be made available to the public for inspection and copying at no more than the actual cost of reproduction. This note applies only to the reference material. The entire text of the rule is printed here.

(1) Alternatives Allowed. All underground storage tank (UST) systems which are in-use must comply with one (1) of the following requirements:

(A) New UST system performance standards in 10 CSR 26-2.020; or

(B) The upgrading requirements in sections (3)–(5) of this rule.

(2) Any UST which was not permanently closed by being removed or filled with an inert, solid material before December 22, 1988, and that does not meet the requirements of section (1) shall be permanently closed in accordance with the requirements in 10 CSR 26-2.060 through 10 CSR 26-2.064. If the UST was taken out of operation by

August 28, 1989, but is still in the ground, the person or party responsible for permanently closing the UST is/are the person(s) who owned the UST immediately before the discontinuation of its use.

(3) Tank Upgrading Requirements. Tanks must be upgraded to meet one (1) of the following requirements in accordance with a code of practice developed by a nationally-recognized association or independent testing laboratory:

(A) Interior lining. A tank may be upgraded by internal lining if—

1. The lining is installed in accordance with the requirements of 10 CSR 26-2.033 and the following:

A. Lining manufacturer installation requirements; and

B. An approved national code or standard, including those listed in section (6) of this rule; and either

C. For steel tanks, structural integrity determinations are required and must include actual steel tank thickness readings. Approved integrity test methods are included in section (6) of this rule; or

D. For fiberglass-reinforced plastic tanks, all linings must be approved by the tank manufacturer and installed in accordance with the tank manufacturer's requirements;

2. Within ten (10) years after the initial lining, and every five (5) years after that, whether relined or not, the lined tank is internally inspected and found to be structurally sound with the lining still performing in accordance with original design specifications; and

3. A tank may only be relined and/or the lining may only be repaired—

A. If the fiberglass-reinforced plastic tank meets all tank manufacturer standards for repair or relining of the tank; or

B. If the steel tank passes an integrity test, including actual steel shell thickness readings. Approved integrity test methods are included in section (6) of this rule;

(B) Cathodic Protection. A tank may be upgraded by cathodic protection if the cathodic protection system meets the requirements of the performance standards for new UST systems in 10 CSR 26-2.020(1)(A)2.B.–D. and the integrity of the tank is ensured using one (1) of the following methods:

1. The tank is internally inspected and assessed to ensure that the tank is structurally sound and free of corrosion holes prior to installing the cathodic protection system. Structural integrity evaluations must include steel shell thickness readings and confirmation that the steel shell does not have any



holes or perforations. Approved integrity test methods are included in section (6) of this rule;

2. The tank has been installed for less than ten (10) years and is monitored monthly for releases in accordance with release detection methods in 10 CSR 26-2.043(1)(E)–(I);

3. The tank has been installed for less than ten (10) years and is assessed for corrosion holes by conducting two (2) tightness tests that meet the requirement of release detection method in 10 CSR 26-2.043(1)(D). The first tightness test must be conducted prior to installing the cathodic protection system. The second tightness test must be conducted between three and six (3–6) months following the first operation of the cathodic protection system; or

4. The tank is assessed for corrosion holes by a method that is determined by the department to prevent releases in a manner that is no less protective of human health and the environment than paragraphs (3)(B)1.–3. of this rule; and

(C) Internal Lining Combined With Cathodic Protection. A tank may be upgraded by both internal lining and cathodic protection if—

1. The lining is installed in accordance with the requirements of 10 CSR 26-2.033; and

2. The cathodic protection system meets the requirements of 10 CSR 26-2.020(1)(A)2.B.–D.

(4) Piping Upgrading Requirements. Metal piping that routinely contains regulated substances and is in contact with an electrolyte, including but not limited to soil, backfill, and/or water, must be cathodically protected in accordance with a code of practice developed by a nationally-recognized association or independent testing laboratory and must meet the requirements of 10 CSR 26-2.020(1)(B)3.B.–D.

(A) New piping installed at an existing facility must comply with the requirements of 10 CSR 26-2.020.

(5) Spill and Overfill Prevention Equipment. To prevent spilling and overfilling associated with product transfer to the UST system, all existing UST systems must comply with new UST system spill and overfill prevention equipment requirements specified in 10 CSR 26-2.020(1)(C).

(6) The following codes and standards may be used to comply with this rule:

(A) American Petroleum Institute Standard 1631, *Interior Lining and Periodic Inspection of Underground Storage Tanks*, revised 2001.

This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the American Petroleum Institute, 1220 L Street NW, Washington, DC 20005, (202) 682-8000, www.api.org/standards/;

(B) NACE International RP 0285-2002, *Corrosion Control of Underground Storage Tank Systems by Cathodic Protection*, revised 2002. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact NACE International, Box 218340, Houston, TX 77218-8340, (713) 492-0535, www.nace.org;

(C) American Petroleum Institute Publication 1632, *Cathodic Protection of Underground Petroleum Storage Tanks and Piping Systems*, revised 2002. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the American Petroleum Institute, 1220 L Street NW, Washington, DC 20005, (202) 682-8000, www.api.org/standards/;

(D) American Society for Testing and Materials G158-98 (2010) *Standard Guide for Three Methods of Assessing Buried Steel Tanks*, revised 2010, Method B only. Methods A and C may not be used to evaluate the integrity of a steel tank. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, (610) 832-9500, www.astm.org; and

(E) National Leak Prevention Association Standard 631, *Spill Prevention, Minimum 10 Year Life Extension of Existing Steel Underground Tanks by Lining Without the Addition of Cathodic Protection*, revised 1999. This standard may only be used for interior lining application and inspection, not for inspection of the steel tank integrity. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the National Leak Prevention Association, (815) 301-2785, www.nlpa-online.org.

AUTHORITY: sections 319.105 and 319.107, RSMo 2000, and section 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.021. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.105, RSMo 1989; 319.107, RSMo 1989, amended 1994; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.022 Notification Requirements

PURPOSE: This rule specifies the registration procedures for underground storage tanks.

(1) Any owner who brings an underground storage tank (UST) system in operation must, within thirty (30) days of bringing the tank into operation, register the completed UST system on forms provided by the department. Note: Owners and operators of UST systems that were in the ground on or after May 8, 1986, unless taken out-of-use on or before January 1, 1974, were required to notify the state in accordance with the Hazardous and Solid Waste Amendments of 1984, P.L. 98-616, on a form published by Environmental Protection Agency (EPA) on November 8, 1985 (50 FR 46602), unless notice was given pursuant to section 103(c) of Comprehensive Environmental Response, Compensation, and Liability Act of 1980 (CERCLA). Owners and operators who have not complied with the notification requirements may use forms provided by the department.

(2) Notices required to be submitted under section (1) of this rule must provide all of the information requested in a form approved by the department for each UST.

(3) All owners and operators of new UST systems must certify in writing compliance with the following requirements:

(A) Installation of tanks and piping in 10 CSR 26-2.020(1)(E);

(B) Cathodic protection of steel tanks and piping under 10 CSR 26-2.020(1)(A) and (B);

(C) Financial responsibility in 10 CSR 26-3.090–10 CSR 26-3.115; and

(D) Release detection in 10 CSR 26-2.040–10 CSR 26-2.045.

(4) If the owner changes, the new owner or operator shall complete and file an updated registration form with the department within thirty (30) days of the change(s).

(5) The department shall issue a Certificate of Registration for any tanks which meet the requirements in sections (1) through (4) of this rule and 10 CSR 26-2.020 and 10 CSR 26-2.021. The Certificate of Registration shall be valid for five (5) years except as described in section (6) of this rule.

(6) The department shall establish effective dates and expiration dates for Certificates of Registration issued under this rule. These



dates shall establish a period of from one to five (1–5) years for an initial Certificate of Registration and a period of five (5) years for subsequent Certificates of Registration.

(7) Information submitted to the department after January 1, 1990, under sections (1) through (4) of this rule for a tank brought into use before January 1, 1990, or for a tank brought into use after September 28, 1990, is an application for a Certificate of Registration and shall be accompanied by a fee as described in section (8).

(8) Fees required under section (7) of this rule shall be paid in one (1) payment of seventy-five dollars (\$75). No fees shall be collected for registration of tanks which were permanently closed prior to August 28, 1989. No further fees shall be assessed upon registered USTs once permanent closure has been completed and any fees to date have been paid.

AUTHORITY: sections 319.103, 319.105, 319.107, 319.111, 319.114, and 319.123, RSMo 2000, and section 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.022. Original rule filed April 2, 1990, effective Sept. 28, 1990. Amended: Filed June 1, 1995, effective Jan. 30, 1996. Amended: Filed Jan. 2, 1996, effective Aug. 30, 1996. Amended: Filed Jan. 14, 1997, effective Sept. 30, 1997. Amended: Filed April 1, 1999, effective March 30, 2000. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.103, RSMo 1989; 319.105, RSMo 1989; 319.107, RSMo 1989, amended 1994; 319.111, RSMo 1989; 319.114, RSMo 1989; 319.123, RSMo 1989; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.030 Spill and Overfill Control

PURPOSE: This rule is designed to prevent releases during routine filling of the underground storage tank with product.

PUBLISHER'S NOTE: The secretary of state has determined that the publication of the entire text of the material which is incorporated by reference as a portion of this rule would be unduly cumbersome or expensive. This material as incorporated by reference in this rule shall be maintained by the agency at its headquarters and shall be made available to the public for inspection and copying at no more than the actual cost of reproduction. This note applies only to the reference material. The entire text of the rule is printed here.

(1) Owners and operators must ensure that

releases due to spilling or overfilling do not occur. The owner and operator must ensure that the volume available in the tank is greater than the volume of product to be transferred to the tank before the transfer is made and that the transfer operation is monitored constantly to prevent overfilling and spilling.

(2) The owner and operator must report, investigate, and clean up any spills and overfills in accordance with 10 CSR 26-2.053.

(3) Guidance on spill and overfill prevention appears in the—

(A) American Petroleum Institute Publication 1621, *Recommended Practice for Bulk Liquid Stock Control at Retail Outlets*, revised 2001. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the American Petroleum Institute, 1220 L Street NW, Washington, DC 20005, (202) 682-8000, www.api.org/standards/; and

(B) National Fire Protection Association Standard 30, *Flammable and Combustible Liquids Code*, revised 2008. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the National Fire Protection Association, 1 Batterymarch Park, Box 9101, Quincy, MA 02269-9101, (617) 770-3000, www.nfpa.org.

AUTHORITY: sections 319.105 and 319.107, RSMo 2000, and section 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.030. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.105, RSMo 1989; 319.107, RSMo 1989, amended 1994; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.031 Operation and Maintenance of Corrosion Protection

PURPOSE: This rule contains the requirements for corrosion protection systems.

PUBLISHER'S NOTE: The secretary of state has determined that the publication of the entire text of the material which is incorporated by reference as a portion of this rule would be unduly cumbersome or expensive. This material as incorporated by reference in this rule shall be maintained by the agency at its headquarters and shall be made available to the public for inspection and copying at no more than the actual cost of reproduction. This note applies only to the

reference material. The entire text of the rule is printed here.

(1) All owners and operators of steel underground storage tank (UST) systems with corrosion protection must comply with the following requirements to ensure that releases due to corrosion are prevented for as long as the UST system is used to store regulated substances.

(A) All corrosion protection systems must be operated and maintained to continuously provide corrosion protection to the metal components of that portion of the tank and piping that routinely contain regulated substances and are in contact with an electrolyte, including but not limited to soil, backfill, and/or water.

(B) All UST systems equipped with cathodic protection systems must be inspected for proper operation by a NACE International certified, Steel Tank Institute certified, or International Code Council (ICC) appropriately certified cathodic protection tester in accordance with the following requirements:

1. Frequency. To confirm that the system is operating properly and providing adequate protection, all cathodic protection systems must be tested within six (6) months of installation and at least triennially after that, or according to another reasonable time frame established by the department; and

2. Inspection criteria. The criteria that are used to determine that cathodic protection (CP) is adequate as required by this section must be in accordance with a code of practice developed by a nationally-recognized association listed in section (2) of this rule.

A. Inspection reports must document the testing method used, the testing standard referenced, the CP tester, and the CP tester's qualifications.

B. Inspection reports must include a site sketch, potential readings, and the location where the readings were made.

C. For impressed current systems, the inspection report must document continuity data and how voltage (IR) drops other than those across the structure/electrolyte interface were considered or accounted for in determining adequate protection.

(C) UST systems with impressed current cathodic protection systems must also be inspected every sixty (60) days to ensure the equipment is running properly.

1. Rectifier log reports must include relevant system data, including but not limited to amperage readings, voltage readings, hour meter, and indicator light, where available.

2. Any indication of deviations from previous rectifier logs or rectifier readings or



the most recent cathodic protection system inspection of the rectifier or cathodic protection system, such as variances in current reading or indicator light, must be appropriately investigated.

(D) For UST systems using cathodic protection, records of the operation of the cathodic protection system must be maintained (in accordance with 10 CSR 26-2.034) to demonstrate compliance with the performance standards in this rule. These records must provide the following:

1. The results of the last three (3) inspections required in subsection (1)(C) of this rule; and

2. The results of testing from the last two (2) inspections required in subsection (1)(B) of this rule.

(2) The following codes and standards may be used to comply with this rule:

(A) NACE International RP 0285-2002, *Corrosion Control of Underground Storage Tank Systems by Cathodic Protection*, revised 2002. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact NACE International, Box 218340, Houston, TX 77218-8340, (713) 492-0535, www.nace.org; or

(B) NACE International TM0101-2001, Standard Test Method, Measurement Techniques Related to Criteria for Cathodic Protection on Underground or Submerged Metallic Tank Systems, 2001 edition. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact NACE International, Box 218340, Houston, TX 77218-8340, (713) 492-0535, www.nace.org; or

(C) Steel Tank Institute Cathodic Protection Testing Procedures for sti-P3 USTs, R051, January 2006. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the Steel Tank Institute, 944 Donata Court, Lake Zurich, IL 60047, (708) 438-8265, www.steeltank.com; or

(D) Steel Tank Institute Recommended Practice for the Addition of Supplemental Anodes to sti-P3 USTs, R972, December 2010. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the Steel Tank Institute, 944 Donata Court, Lake Zurich, IL 60047, (708) 438-8265, www.steeltank.com.

(3) If cathodic protection is being used to protect all or part of a UST system from corrosion, and the electric system energizing the cathodic protection has been off, unhooked,

or damaged for more than ninety (90) days, the owner/operator must—

(A) Conduct an integrity test, documenting adequate tank shell integrity and thickness, as required in 10 CSR 26-2.021(3)(B); and

(B) Have a corrosion expert or design engineer re-evaluate the UST system, cathodic protection system, and surrounding structures and design and/or make changes to the existing cathodic protection system to meet the standards in 10 CSR 26-2.020(1)(A)2.B.–D.

(C) The owner/operator may request an additional ninety (90) days to repair the systems by submitting a request, including the justification for the extension; or

(D) Permanently close the tank, in accordance with 10 CSR 26-2.060 through 10 CSR 26-2.064.

(4) If a cathodic protection system test indicates that the system is not operating properly or does not provide adequate protection, as defined by the testing method used, and the system is not repaired or does not pass a re-test within ninety (90) days, or if a required cathodic protection system test is not conducted, the owner/operator must comply with the requirements outlined in section (3) of this rule.

AUTHORITY: sections 319.105 and 319.107, RSMo 2000, and section 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.031. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.105, RSMo 1989; 319.107, RSMo 1989, amended 1994; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.032 Compatibility

PURPOSE: This rule prevents releases caused by chemical action on the underground storage tank system by the stored regulated substance.

PUBLISHER'S NOTE: The secretary of state has determined that the publication of the entire text of the material which is incorporated by reference as a portion of this rule would be unduly cumbersome or expensive. This material as incorporated by reference in this rule shall be maintained by the agency at its headquarters and shall be made available to the public for inspection and copying at no more than the actual cost of reproduction. This note applies only to the reference material. The entire text of the rule is printed here.

(1) Owners and operators must use an underground storage tank (UST) system made of or lined with materials that are compatible with the substance stored in the UST system. If a lining is installed for compatibility purposes, it must be maintained and inspected in accordance with 10 CSR 26-2.021(3)(A).

(2) Owners and operators storing alcohol blends may use the following codes to comply with this rule:

(A) American Petroleum Institute Publication 1626, *Storing and Handling Ethanol and Gasoline-Ethanol Blends at Distribution Terminals and Service Stations*, revised 2001. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the American Petroleum Institute, 1220 L Street NW, Washington, DC 20005, (202) 682-8000, www.api.org/standards/; or

(B) American Petroleum Institute Publication 1627, *Storage and Handling of Gasoline-Methanol/Cosolvent Blends at Distribution Terminals and Service Stations*, revised 2001. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the American Petroleum Institute, 1220 L Street NW, Washington, DC 20005, (202) 682-8000, www.api.org/standards/; or

(C) Other standards or publications approved by the department.

AUTHORITY: section 319.105, RSMo 2000, and section 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.032. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.105, RSMo 1989 and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.033 Repairs Allowed

PURPOSE: This rule describes methods for repair of underground storage tank systems.

PUBLISHER'S NOTE: The secretary of state has determined that the publication of the entire text of the material which is incorporated by reference as a portion of this rule would be unduly cumbersome or expensive. This material as incorporated by reference in this rule shall be maintained by the agency at its headquarters and shall be made available to the public for inspection and copying at no more than the actual cost of reproduction. This note applies only to the



reference material. The entire text of the rule is printed here.

(1) Owners and operators of underground storage tank (UST) systems must ensure that repairs will prevent releases due to structural failure or corrosion as long as the UST system is used to store regulated substances.

(2) The repairs must meet the following requirements:

(A) Repairs to UST systems must be properly conducted in accordance with a code of practice developed by a nationally-recognized association or an independent testing laboratory.

1. The following codes and standards may be used to comply with subsection (2)(A) of this rule:

A. National Fire Protection Association Standard 30, *Flammable and Combustible Liquids Code*, revised 2008. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the National Fire Protection Association, 1 Batterymarch Park, Box 9101, Quincy, MA 02269-9101, (617) 770-3000, www.nfpa.org;

B. American Petroleum Institute Publication 2200, *Repairing Crude Oil, Liquefied Petroleum Gas, and Product Pipelines*, revised 2001. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the American Petroleum Institute, 1220 L Street NW, Washington, DC 20005, (202) 682-8000, www.api.org/standards/;

C. American Petroleum Institute Standard 1631, *Interior Lining and Periodic Inspection of Underground Storage Tanks*, revised 2001. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the American Petroleum Institute, 1220 L Street NW, Washington, DC 20005, (202) 682-8000, www.api.org/standards/; and

D. National Leak Prevention Association Standard 631, *Spill Prevention, Minimum 10-Year Life Extension of Existing Steel Underground Tanks by Lining Without the Addition of Cathodic Protection*, revised 1999. This standard may only be used for interior lining application and inspection, not for integrity testing of the steel shell. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the National Leak Prevention Association, (815) 301-2785, www.nlpa-online.org;

(B) Repairs to fiberglass-reinforced plastic tanks may be made by the manufacturer's

authorized representatives or in accordance with a code of practice developed by a nationally-recognized association or an independent testing laboratory;

(C) Metal pipe sections and fittings that have released a regulated substance as a result of corrosion or other damage must be replaced. For cathodically protected metal piping, the entire length of electrically-continuous metal pipe must be replaced. Fiberglass pipes and fittings may be repaired in accordance with the manufacturer's specifications;

(D) Repairs must be done by a person who is properly registered with the Missouri Department of Agriculture and who has a financial responsibility mechanism that complies with the requirements of 2 CSR 90-30.085;

(E) Repaired tanks and piping must be tightness tested in accordance with release detection methods listed in 10 CSR 26-2.043(1)(D) and 10 CSR 26-2.044(1)(B) within thirty (30) days following the date of the completion of the repair, except as provided in the following paragraphs:

1. The repaired tank is internally inspected in accordance with a code of practice developed by a nationally-recognized association or an independent testing laboratory;

2. The repaired portion of the UST system is monitored monthly for releases by one (1) of the release detection methods listed in 10 CSR 26-2.043(1)(B) and (E)-(I); or

3. Another test method is used that is determined by the department to be no less protective of human health and the environment than those listed in paragraphs (2)(E)1. and 2. of this rule;

(F) Within six (6) months following the repair of any cathodically protected UST system, the cathodic protection system must be tested with the methods for operation and maintenance of corrosion protection in 10 CSR 26-2.031(1)(B) and (C) to ensure that it is operating properly. Repair may include, but is not limited to, adjustments, maintenance, replacement, or changes to cathodic protection equipment and/or tank repairs;

(G) If a tank is repaired by installation of an interior lining, the lining must be properly maintained and inspected, in accordance with 10 CSR 26-2.021(3)(A), for the life of the tank; and

(H) UST system owners and operators must maintain records of each repair for the remaining operating life of the UST system that demonstrate compliance with the requirements of this rule.

AUTHORITY: sections 319.105 and 319.107, RSMo 2000, and section 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.033. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.105, RSMo 1989; 319.107, RSMo 1989, amended 1994; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.034 Reporting and Record Keeping

PURPOSE: This rule explains how the owner and operator must keep records demonstrating compliance with the requirements of this chapter. These records must be furnished to the department on request.

(1) Owners and operators of underground storage tank (UST) systems must cooperate fully with inspections, monitoring, and testing conducted by the department, or the department's authorized representative, as well as requests for document submission, testing, and monitoring by the owner or operator.

(A) Reporting. Owners and operators must submit the following information to the department:

1. Notification for all UST systems by the notification requirements in 10 CSR 26-2.022;

2. Reports of all releases including suspected releases (10 CSR 26-2.050), spills and overfills (10 CSR 26-2.053), and confirmed releases (10 CSR 26-2.071);

3. Corrective actions planned or taken including initial abatement measures (10 CSR 26-2.072), initial site characterization (10 CSR 26-2.074), free product removal (10 CSR 26-2.075), investigation of soil and groundwater cleanup (10 CSR 26-2.078), and corrective action plan (10 CSR 26-2.082); and

4. A notification before permanent closure or change in service (10 CSR 26-2.061).

(B) Record Keeping. Owners and operators must maintain the following information:

1. A corrosion expert's analysis of site corrosion potential if corrosion protection equipment is not used (10 CSR 26-2.020(1)(A)4. and (1)(B)4.);

2. Documentation of operation of corrosion protection equipment (10 CSR 26-2.031);

3. Documentation of UST system repairs (10 CSR 26-2.033(2)(H));

4. Recent compliance with release detection requirements (10 CSR 26-2.045); and



5. Results of the site investigation conducted at permanent closure (10 CSR 26-2.064).

(C) Availability and Maintenance of Records. Owners and operators must keep the records required either—

1. At the UST site and immediately available for inspection by the department; or

2. At a readily available alternative site and be provided for inspection to the department within three (3) working days or five (5) calendar days upon receipt of a written request. A written request shall be made in the following manner:

A. The department shall provide a written request at the time of inspection to site personnel; or

B. In the cases of unattended sites or inspections conducted after normal business hours, written notice shall be made by certified mail; or

3. If the owner or operator fails to meet the requirements of paragraph (1)(C)2., the department may order or otherwise require that owner or operator to maintain records on-site per paragraph (1)(C)1.; or

4. In the case of permanent closure records required under 10 CSR 26-2.064, owners and operators are also provided with the additional alternative of mailing closure records to the department if they cannot be kept at the site or an alternative site as indicated in this section.

*AUTHORITY: sections 319.107 and 319.111, RSMo 2000, and section 319.137, RSMo Supp. 2010. * This rule originally filed as 10 CSR 20-10.034. Original rule filed April 2, 1990, effective Sept. 28, 1990. Amended: Filed Aug. 3, 1993, effective April 9, 1994. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.107, RSMo 1989, amended 1994; 319.111, RSMo 1989; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.040 General Requirements for Release Detection for All Underground Storage Tank Systems

PURPOSE: This rule outlines the minimum requirements for leak and spill detection systems.

(1) Owners and operators of underground storage tank (UST) systems that are in use must use a method, or combination of methods, or release detection that—

(A) Can detect a release from any portion of the tank and the connected underground piping that routinely contains a regulated substance, except remote fills and gravity piping;

(B) Is installed, calibrated, operated, and maintained in accordance with the manufacturer's instructions, including routine maintenance and service checks for operability or running condition; and

(C) Meets the performance requirements for tanks in 10 CSR 26-2.043 or for piping in 10 CSR 26-2.044, with any performance claims and their manner of determination described in writing by the equipment manufacturer or installer. In addition, all release detection methods must be capable of detecting the leak rate or quantity specified for that tank method in 10 CSR 26-2.043 or piping method in 10 CSR 26-2.044 with a probability of detection of ninety-five percent (95%) and a probability of false alarm of five percent (5%).

(D) All release detection methods and equipment must be conducted and operated in accordance with the applicable National Work Group on Leak Detection Evaluations (NWGLDE) certification, unless otherwise approved by the department. To obtain copies of equipment certifications, contact the National Work Group for Leak Detection Evaluations, www.nwglde.org.

(2) When a release detection method for tanks in 10 CSR 26-2.043 or for piping in 10 CSR 26-2.044 indicates a release may have occurred, owners and operators must notify the department in accordance with 10 CSR 26-2.050–10 CSR 26-2.053.

*AUTHORITY: sections 319.105, 319.107, and 319.111, RSMo 2000, and section 319.137, RSMo Supp. 2010. * This rule originally filed as 10 CSR 20-10.040. Original rule filed April 2, 1990, effective Sept. 28, 1990. Amended: Filed Aug. 3, 1993, effective April 9, 1994. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.105, RSMo 1989; 319.107, RSMo 1989, amended 1994; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.041 Requirements for Petroleum Underground Storage Tank Systems

PURPOSE: This rule outlines the options for leak detection at petroleum underground storage tanks.

(1) Owners and operators of petroleum underground storage tanks (UST) systems that are in use must provide release detection for tanks and piping as follows:

(A) Tanks. Tanks must be monitored at least every thirty (30) days for releases using

one (1) of the methods listed in 10 CSR 26-2.043(1)(B)–(I), except that—

1. UST systems that meet new or upgraded standards in 10 CSR 26-2.020 or 10 CSR 26-2.021 and the monthly inventory control requirements in 10 CSR 26-2.043(1)(A) may use tank tightness testing (10 CSR 26-2.043(1)(D)) at least every five (5) years until December 22, 1998, or until ten (10) years after the tank is installed or upgraded under 10 CSR 26-2.021(3), whichever is later;

2. Tanks with a capacity of five hundred fifty (550) gallons or less may use manual tank gauging (10 CSR 26-2.043(1)(C)); and

(B) Piping. Underground piping that routinely contains regulated substances must be monitored for releases in a manner that meets one (1) of the following requirements:

1. Pressurized piping. Underground piping that conveys regulated substances under pressure must—

A. Be equipped with an automatic line leak detector in 10 CSR 26-2.044(1)(A); and

B. Have an annual line tightness test conducted in accordance with 10 CSR 26-2.044(1)(B) or have monthly monitoring conducted in accordance with 10 CSR 26-2.044(1)(C); and

2. Suction piping. Underground piping that conveys regulated substances under suction must either have a line tightness test conducted at least every three (3) years and in accordance with 10 CSR 26-2.044(1)(B) or use a monthly monitoring method conducted in accordance with 10 CSR 26-2.044(1)(C). No release detection is required for suction piping that is designed and constructed to meet the following standards:

A. The below-grade piping operates at less than atmospheric pressure;

B. The below-grade piping is sloped so that the contents of the pipe will drain back into the storage tank if the suction is released;

C. Only one (1) check valve is included in each suction line;

D. The check valve is located directly below and as close as practical to the suction pump; and

E. A method is provided that allows compliance with subparagraphs (1)(B)2.A.–D. of this rule to be readily determined (for example, the check valve can be visually inspected); and

3. Gravity piping and remote fill piping are exempt from the piping line leak detection requirements in this section.

(2) High-throughput Facilities. In addition to the requirements outlined in section (1) of



this rule, any owner of a tank or a multi-tank connected or manifolded system that dispenses more than eight hundred thousand (800,000) gallons of any regulated substance in one (1) calendar month must use at least one (1) of the following tank system release detection methods:

(A) Continuous, electronic interstitial monitoring for both tank and piping systems, in accordance with 10 CSR 26-2.043(1)(H), documenting passing readings at least once every thirty (30) days; or

(B) Vapor monitoring, including introduced chemical marker monitoring, approved by the National Work Group for Leak Detection Evaluations (NWGLDE) for the substance stored at least once every fifteen (15) days. To obtain copies of equipment certifications, contact the National Work Group for Leak Detection Evaluations, www.nwglde.org; or

(C) Continuous in-tank release detection, which must include continual reconciliation of tank system inventory. Standard statistical inventory control is not acceptable. The method used must meet criteria established by the National Work Group for Leak Detection Evaluations (NWGLDE) for continuous in-tank leak detection methods. To obtain copies of equipment certifications, contact the National Work Group for Leak Detection Evaluations, www.nwglde.org; or

(D) Another method approved by the department specifically for high-throughput UST systems.

AUTHORITY: sections 319.105 and 319.107, RSMo 2000, and section 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.041. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.105, RSMo 1989; 319.107, RSMo 1989, amended 1994; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.042 Requirements for Hazardous Substance Underground Storage Tank Systems

PURPOSE: This rule outlines the standards for leak detection on hazardous substance underground storage tanks.

(1) Owners and operators of in-use hazardous substance underground storage tank (UST) systems must use a release detection method that meets the requirements of 10 CSR 26-2.041.

(2) In addition, all in-use hazardous substance USTs must meet the following require-

ments:

(A) Secondary containment systems must be designed, constructed, and installed to—

1. Contain regulated substances released from the tank system until they are detected and removed;

2. Prevent the release of regulated substances to the environment at any time during the operational life of the UST system; and

3. Be checked for evidence of a release at least every thirty (30) days;

(B) Double-walled tanks must be designed, constructed, and installed to—

1. Contain a release from any portion of the inner tank within the outer wall; and

2. Detect the failure of the inner wall;

(C) External liners (including vaults) must be designed, constructed, and installed to—

1. Contain one hundred percent (100%) of the capacity of the largest tank within its boundary;

2. Prevent the interference of precipitation or groundwater intrusion with the ability to contain or detect a release of regulated substances; and

3. Surround the tank completely (that is, it is capable of preventing lateral as well as vertical migration of regulated substances);

(D) Underground piping must be equipped with secondary containment that satisfies the requirements of subsection (2)(A) of this rule (for example, trench liners, jacketing of double-walled pipe). In addition, underground piping that conveys regulated substances under pressure must be equipped with an automatic line leak detector in 10 CSR 26-2.044(1)(A); and

(E) Other methods of release detection may be used if owners and operators—

1. Demonstrate to the department that an alternative method can detect a release of the stored substance as effectively as any of the methods allowed in 10 CSR 26-2.043(1)(B)–(I) can detect a release of petroleum;

2. Provide information to the department on effective corrective action technologies, health risks, and chemical and physical properties of the stored substance and the characteristics of the UST site; and

3. Obtain approval from the department to use the alternate release detection method before the installation and operation of the new UST system.

AUTHORITY: sections 319.105 and 319.107, RSMo 2000, and section 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.042. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.105, RSMo 1989; 319.107, RSMo 1989, amended 1994; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.043 Methods of Release Detection for Tanks

PURPOSE: This rule contains the requirements that specific underground storage tank leak detection methods must meet.

(1) Methods of release detection for underground storage tanks (USTs) used to meet the requirements in 10 CSR 26-2.041 must be conducted as follows:

(A) Inventory Control. Regulated substance inventory control (or another test of equivalent performance) must be conducted monthly to detect a release of at least one percent (1%) of flow through plus one hundred thirty (130) gallons on a monthly basis in the following manner:

1. Inventory volume measurements for regulated substance inputs, withdrawals, and the amount still remaining in the tank are recorded each operating day on forms provided by the department or on forms previously approved by the department;

2. The equipment used is capable of measuring the level of regulated substance over the full range of the tank's height to the nearest one-eighth inch (1/8");

3. The regulated substance inputs are reconciled with delivery receipts by measurement of the tank inventory volume before and after delivery;

4. Deliveries are made through a drop tube that extends to within one foot (1') of the tank bottom;

5. Product dispensing is metered and recorded within the local standards for meter calibration or an accuracy of six (6) cubic inches for every five (5) gallons of product withdrawn;

6. The measurement of any water level in the bottom of the tank is made to the nearest one-eighth inch (1/8") at least once a month; and

7. The practices described in the American Petroleum Institute Publication 1621, *Recommended Practice for Bulk Liquid Stock Control at Retail Outlets*, revised 2001, may be used, where applicable, as guidance in meeting the requirements of this subsection;

(B) Statistical Inventory Reconciliation (SIR), which is a statistical inventory analysis method that tests for the loss of a regulated substance. SIR must meet the following requirements:

1. Be able to detect a two-tenths (0.2) gallon-per-hour leak rate from any portion of



the tank system that routinely contains a regulated substance;

2. Must be conducted for each independent tank system;

3. Be done in conjunction with inventory control that meets the requirements in 10 CSR 26-2.043(1)(A); and

4. Be conducted in accordance with the National Work Group on Leak Detection Evaluations certification and the manufacturer's requirements. To obtain copies of equipment certifications, contact the National Work Group for Leak Detection Evaluations, www.nwglde.org;

5. Owners and operators must maintain all supporting data, including regulated substance and water stick readings, for at least twelve (12) months.

6. The SIR analysis report must be completed and sent to the owner or operator within fifteen (15) days of the end of each calendar month;

(C) Manual Tank Gauging. Manual tank gauging must meet the following requirements:

1. Tank liquid level measurements are taken at the beginning and ending of a period of at least thirty-six (36) hours during which no liquid is added to or removed from the tank;

2. Level measurements are based on an average of two (2) consecutive stick readings at both the beginning and ending of the period;

3. The equipment used is capable of measuring the level of regulated substance over the full range of the tank's height to the nearest one-eighth inch (1/8");

4. A leak is suspected and subject to the requirements of 10 CSR 26-2.050–10 CSR 26-2.053 if the variation between beginning and ending measurements exceeds the following weekly or monthly standards:

A. Tanks of five hundred fifty (550)-gallon capacity or less are allowed a weekly standard of ten (10) gallons per reading and a monthly average of five (5) gallons per reading;

B. Five hundred fifty-one to one thousand (551–1,000)-gallon capacity tanks are allowed a difference of thirteen (13) gallons per week and a monthly average of seven (7) gallons;

C. One thousand one to two thousand (1,001–2,000)-gallon capacity tanks are allowed a difference of twenty-six (26) gallons per week and a monthly average of thirteen (13) gallons;

D. Five hundred fifty-one to one thousand (551–1,000)-gallon capacity tanks with dimensions no greater than sixty-four inches by seventy-three inches (64" × 73")

are allowed a difference of nine (9) gallons per week and monthly average of four (4) gallons, provided that a period of at least forty-four (44) hours during which no liquid is added to or removed from the tank is allowed to pass between tank liquid level measurements; and

E. One thousand (1,000)-gallon capacity tanks with dimensions of forty-eight inches by one hundred twenty-eight inches (48" × 128") are allowed a difference of twelve (12) gallons per week and a monthly average of six (6) gallons, provided that a period of at least fifty-eight (58) hours during which no liquid is added to or removed from the tank is allowed to pass between tank liquid level measurements; and

5. Use of manual tank gauging must comply with the following size restrictions:

A. Tanks of five hundred fifty (550) gallons or less nominal capacity may use this as the sole method of release detection;

B. Tanks of five hundred fifty-one to one thousand (551–1,000)-gallon capacity with dimensions no greater than sixty-four inches by seventy-three inches (64" × 73") and tanks of one thousand (1,000)-gallon capacity with dimensions of forty-eight inches by one hundred twenty-eight inches (48" × 128") may use this as the sole method of release detection;

C. Tanks of five hundred fifty-one to two thousand (551–2,000) gallons may use the method in place of inventory control in 10 CSR 26-2.043(1)(A); and

D. Tanks of greater than two thousand (2,000) gallons nominal capacity may not use this method for release detection;

(D) Tank Tightness Testing. Tank tightness testing (or similar test) must be capable of detecting a one-tenth (0.1)-gallon-per-hour leak rate from any portion of the tank that routinely contains regulated substance while accounting for the effects of thermal expansion or contraction of the regulated substance, vapor pockets, tank deformation, evaporation or condensation, and the location of the water table;

(E) Automatic Tank Gauging. Equipment for automatic tank gauging that tests for the loss of regulated substance and conducts inventory control must meet the following requirements:

1. The automatic regulated substance level monitor test can detect a two-tenths (0.2)-gallon-per-hour leak rate from any portion of the tank that routinely contains a regulated substance; and

2. Inventory control (or equivalent test) meeting the requirements in 10 CSR 26-2.043(1)(A) is conducted;

(F) Vapor Monitoring. Testing or monitor-

ing for vapors within the soil gas of the excavation zone must meet the following requirements:

1. The materials used as backfill are sufficiently porous and permeable (for example, gravel, sand, or crushed rock) to readily allow diffusion of vapors from releases into the excavation area;

2. The stored regulated substance, or a tracer compound placed in the tank system, is sufficiently volatile (for example, gasoline) to result in a vapor level that is detectable by the monitoring devices located in the excavation zone in the event of a release from the tank;

3. The measurement of vapors by the monitoring device is not rendered inoperative by the groundwater, rainfall, or soil moisture or other known interferences so that a release could go undetected for more than thirty (30) days;

4. The level of background contamination in the excavation zone will not interfere with the method used to detect releases from the tank;

5. The vapor monitors are designed and operated to detect any significant increase in concentration above background of the regulated substance stored in the tank system, a component(s) of that substance, or a tracer compound placed in the tank system;

6. In the UST excavation zone, the site is assessed to ensure compliance with the requirements in paragraphs (1)(F)1.–4. of this rule and to establish the number and positioning of monitoring wells that will detect releases within the excavation zone from any portion of the tank that routinely contains a regulated substance; and

7. Monitoring wells are clearly marked and secured to avoid unauthorized access and tampering;

(G) Groundwater Monitoring. Testing or monitoring for liquids on the groundwater must meet the following requirements:

1. The regulated substance stored is immiscible in water and has a specific gravity of less than one (1);

2. The groundwater is within twenty feet (20') from the ground surface and the hydraulic conductivity of the soil(s) between the UST system and the monitoring wells or devices is at least one hundredth centimeter per second (0.01 cm/sec) (for example, the soil should consist of gravels, coarse to medium sands, coarse silts, or other permeable materials);

3. The slotted portion of the monitoring well casing must be designed to prevent migration of natural soils or filter pack into the well and to allow entry of regulated substance on the water table into the well under both high and low groundwater conditions;



4. Monitoring wells shall be sealed from the ground surface to the top of the filter pack;

5. Monitoring wells or devices shall intercept the excavation zone or are as close to it as is technically feasible;

6. The continuous monitoring devices or manual methods used can detect the presence of at least one-eighth inch (1/8") of free product on top of the groundwater in the monitoring wells;

7. The site is assessed within and immediately below the UST system excavation zone to ensure compliance with the requirements in paragraphs (1)(G)1.-5. of this rule. The site assessment also establishes the number and positioning of monitoring wells or devices that will detect releases from any portion of the tank that routinely contains a regulated substance; and

8. Monitoring wells are clearly marked and secured to avoid unauthorized access and tampering;

(H) Interstitial Monitoring. Interstitial monitoring between the UST system and a secondary barrier immediately around or beneath it may be used, but only if the system is designed, constructed, and installed to detect a leak from any portion of the tank that routinely contains a regulated substance and also meets one (1) of the following requirements:

1. For double-walled UST systems, the sampling or testing method can detect a release through the inner wall in any portion of the tank that routinely contains a regulated substance;

2. For UST systems with a secondary barrier within the excavation zone, the sampling or testing method used can detect a release between the UST system and the secondary barrier.

A. The secondary barrier around or beneath the UST system consists of artificially constructed material that is sufficiently thick and impermeable (less than one millionth centimeter per second (10^{-6} cm/sec) for the regulated substance stored) to direct a release to the monitoring point and permit its detection.

B. The barrier is compatible with the regulated substance stored so that a release from the UST system will not cause a deterioration of the barrier allowing a release to pass through undetected.

C. For cathodically protected tanks the secondary barrier must be installed so that it does not interfere with the proper operation of the cathodic protection system.

D. The groundwater, soil moisture, or rainfall will not render the testing or sampling method used inoperative so that a

release could go undetected for more than thirty (30) days.

E. The site is assessed to ensure that the secondary barrier is always above the groundwater and not in a twenty-five (25)-year flood plain, unless the barrier and monitoring designs are for use under these conditions.

F. Monitoring wells are clearly marked and secured to avoid unauthorized access and tampering;

3. For tanks with an internally fitted liner, an automated device can detect a release between the inner wall of the tank and the liner is compatible with the substance stored; and

4. The provisions outlined in the Steel Tank Institute's *Standard for Dual Wall Underground Storage Tanks* may be used as guidance for aspects of the design and construction of underground steel double-walled tanks; and

(I) Other Methods. Any other type of release detection method, or combination of methods, can be used if—

1. It can detect a two-tenths (0.2)-gallon-per-hour leak rate or a release of one hundred fifty (150) gallons within a month with a probability of detection of ninety-five percent (95%) and a probability of false alarm of five percent (5%); or

2. The department may approve another method if the owner and operator can demonstrate that the method can detect a release as effectively as any of the methods allowed in subsections (1)(C)–(H) of this rule. In comparing methods, the department shall consider the size of release that the method can detect and the frequency and reliability with which it can be detected. If the method is approved, the owner and operator must comply with any conditions imposed by the department on its use to ensure the protection of human health and the environment.

AUTHORITY: sections 319.105 and 319.107, RSMo 2000, and section 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.043. Original rule filed April 2, 1990, effective Sept. 28, 1990. Amended: Filed Aug. 3, 1993, effective April 9, 1994. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.105, RSMo 1989; 319.107, RSMo 1989, amended 1994; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.044 Methods of Release Detection for Piping

PURPOSE: This rule describes the requirements of leak detection for the piping on underground storage tanks.

(1) Each method of release detection for piping used to meet the requirements of release detection for underground storage tanks (USTs) in 10 CSR 26-2.041 must be conducted in the following manner:

(A) Automatic Line Leak Detectors. Methods which alert the operator to the presence of a leak by restricting or shutting off the flow of regulated substances through piping or triggering an audible or visual alarm may be used only if they detect leaks of three (3) gallons per hour at ten (10) pounds per square-inch line pressure within one (1) hour and are certified by the National Work Group on Leak Detection Evaluations. To obtain copies of equipment certifications, contact the National Work Group for Leak Detection Evaluations, www.nwglde.org. A test of the operation of the leak detector must be conducted at least annually. The annual test must be conducted in accordance with the manufacturer's approved testing procedures.

1. Line leak detectors must monitor all pressurized piping, including pressurized piping beyond the first or master dispenser but not including other piping above the shear valve inside the dispenser or dispenser hoses to the nozzle.

2. Line leak detector operability test reports must include facility name and address, line leak detector manufacturer, model and serial number, if legible, testing date, test method, technician name and affiliation, and a certification of results;

(B) Line Tightness Testing. A periodic test of piping may be conducted only if it can detect a one-tenth (0.1)-gallon-per-hour leak rate at one and one-half (1.5) times the operating pressure;

(C) Applicable Tank Methods. Any of the methods in 10 CSR 26-2.043(1)(B) and (F)–(I) may be used if they are designed to detect a release from any portion of the underground piping that routinely contains regulated substances; and

(D) Emergency Generator Tanks. For a tank that stores fuel solely for use by an emergency generator, or a tank that stores fuel for an emergency generator and heating oil for consumptive use on the premises where stored, interstitial line monitoring with sump sensors, an alarm, and secondary containment may be used on pressurized lines in lieu of the automatic line leak detector, required in 10 CSR 26-2.041 and subsection (1)(A) of this rule.



AUTHORITY: sections 319.105 and 319.107, RSMo 2000, and section 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.044. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.105, RSMo 1989; 319.107, RSMo 1989, amended 1994; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.045 Release Detection Record Keeping

PURPOSE: This rule describes the records that must be maintained for monthly release detection activity.

(1) All underground storage tank (UST) system owners and operators must maintain records in 10 CSR 26-2.034 demonstrating compliance with applicable release detection requirements in 10 CSR 26-2.040–10 CSR 26-2.045. These records must include the following:

(A) All written performance claims of any release detection system used, and the manner in which these claims have been justified or tested by the equipment manufacturer or installer, must be maintained for five (5) years or for another reasonable period of time determined by the department from the date of installation;

(B) The results of any sampling, testing, or monitoring must be maintained for at least one (1) year, or for another reasonable period of time determined by the department, except that the results of tank tightness testing conducted in accordance with 10 CSR 26-2.043(1)(D) must be retained until the next test is conducted; and

(C) Written documentation of all calibration, maintenance, and repair of release detection equipment permanently located on-site must be maintained for at least one (1) year after the servicing work is completed. Any schedules of required calibration and maintenance provided by the release detection equipment manufacturer must be retained for five (5) years from the date of installation.

AUTHORITY: sections 319.105 and 319.107, RSMo 2000, and section 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.045. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.105, RSMo 1989; 319.107, RSMo 1989, amended 1994; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.050 Reporting of Suspected Releases

PURPOSE: This rule describes the steps for reporting leaks and spills.

(1) Owners and operators of underground storage tank (UST) systems must report to the department within twenty-four (24) hours and follow the procedures for release investigation and confirmation in 10 CSR 26-2.052 upon discovery of one (1) or more of the following conditions:

(A) The discovery by owners and operators or others of released regulated substances at the UST site or in the surrounding area (such as the presence of free product or vapors in soils, basements, sewer and utility lines, and nearby surface water);

(B) Unusual operating conditions observed by owners and operators (such as the erratic behavior of product dispensing equipment, the sudden loss of a regulated substance from the UST system, an unexplained presence of water in the tank, or visible leaks from above-ground piping or ancillary equipment connected to a UST), unless system equipment is found to be defective but not leaking and is immediately repaired or replaced; or

(C) Monitoring results from a release detection method required under 10 CSR 26-2.041 and 10 CSR 26-2.042 that indicate a release may have occurred unless—

1. The monitoring device is found to be defective and is immediately repaired, recalibrated, or replaced and additional monitoring does not confirm the initial result; or

2. In the case of inventory control, a second month of data does not confirm the initial result.

AUTHORITY: section 319.109, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.050. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.109, RSMo 1989, amended 1995, 2004, 2008.*

10 CSR 26-2.051 Investigation Due to Off-Site Impacts

PURPOSE: This rule describes the requirements for off-site investigations following reported or suspected releases.

(1) When required by the department, owners and operators of underground storage tank (UST) systems must follow the steps for confirmation of a release in 10 CSR 26-2.052 to

determine if the UST system is the source of the off-site impacts. These impacts include the discovery of regulated substances such as the presence of free product or vapors in soils, basements, sewer and utility lines, and nearby surface and drinking waters that have been observed by the department or brought to its attention by another party.

AUTHORITY: section 319.107, RSMo 2000, and sections 319.109 and 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.051. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.107, RSMo 1989, amended 1994; 319.109, RSMo 1989, amended 1995, 2004, 2008; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.052 Release Investigation and Confirmation Steps

PURPOSE: This rule describes the steps needed to verify a release.

(1) Unless corrective action is initiated in accordance with 10 CSR 26-2.070–10 CSR 26-2.083, owners and operators must immediately investigate and confirm all suspected releases of regulated substances requiring reporting under 10 CSR 26-2.050 within seven (7) days or another reasonable time period specified by the department using either the following steps or another procedure approved by the department:

(A) System Test. Owners and operators must conduct tests (tightness testing of tanks in 10 CSR 26-2.043(1)(D) and piping in 10 CSR 26-2.044(1)(B)) to determine whether a leak exists in that portion of the tank that routinely contains a regulated substance or the attached delivery piping or both.

1. Owners and operators must repair, replace, or upgrade the underground storage tank (UST) system, and begin site check in accordance with subsection (1)(B) and corrective action in 10 CSR 26-2.070–10 CSR 26-2.083 if the test results for the system, tank, or delivery piping indicate that a leak exists.

2. Further investigation is not required if the test results for the system, tank, and delivery piping do not indicate that a leak exists and if environmental contamination is not the basis for suspecting a release.

3. Owners and operators must conduct a site check as described in subsection (1)(B) of this rule if the test results for the system, tank, and delivery piping do not indicate that a leak exists but environmental contamination is the basis for suspecting a release; or



(B) Site Check. Owners and operators must measure for the presence of a release where contamination is most likely to be present at the UST site. In selecting sample types, sample locations, and measurement methods, owners and operators must consider the nature of the stored substance, the type of initial alarm or cause for suspicion, the type of backfill, the depth of groundwater, and other factors appropriate for identifying the presence and source of the release.

1. If the site check indicates that a release has occurred, owners and operators must begin site characterization and corrective action in accordance with 10 CSR 26-2.070–10 CSR 26-2.083; or

2. If the results of the site check do not indicate that a release has occurred, the investigation may stop.

(2) Owners and operators shall follow a written procedure. A copy of the written procedure or, if the written procedure is commonly available, a clear reference to the written procedure shall be submitted to and approved by the department prior to beginning activities required by this rule.

AUTHORITY: sections 319.105 and 319.107, RSMo 2000, and sections 319.109 and 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.052. Original rule filed April 2, 1990, effective Sept. 28, 1990. Amended: Filed Aug. 3, 1993, effective April 9, 1994. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.105, RSMo 1989; 319.107, RSMo 1989, amended 1994; 319.109, RSMo 1989, amended 1995, 2004, 2008; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.053 Reporting and Cleanup of Spills and Overfills

PURPOSE: This rule describes the steps for reporting and cleanup of spills.

(1) Owners and operators of underground storage tank (UST) systems must contain and immediately clean up a spill or overflow. The spill or overflow must be reported to the department within twenty-four (24) hours. Owners and operators must begin site check, in accordance with 10 CSR 26-2.052(1)(B), and corrective action in accordance with 10 CSR 26-2.070–10 CSR 26-2.083 in the following cases:

(A) Spill or overflow of petroleum that results in a release to the environment that exceeds twenty-five (25) gallons or that causes a sheen on nearby surface water; and

(B) Spill or overflow of a hazardous sub-

stance that results in a release to the environment that equals or exceeds its reportable quantity under Comprehensive Environmental Response Compensation and Liability Act of 1980 (CERCLA) (40 CFR 302).

(2) Owners and operators of UST systems must contain and immediately clean up a spill or overflow of petroleum that is less than twenty-five (25) gallons or another reasonable amount specified by the department and a spill or overflow of a hazardous substance that is less than the reportable quantity. If cleanup cannot be accomplished within twenty-four (24) hours, owners and operators must immediately notify the department.

(3) A release of a hazardous substance equal to or in excess of its reportable quantity must also be reported immediately (rather than within twenty-four (24) hours) to the National Response Center under Sections 102 and 103 of CERCLA (40 CFR 302.6) and to appropriate state and local authorities under Title III of the Superfund Amendments and Reauthorization Act of 1986 (40 CFR 355.40).

AUTHORITY: section 319.109, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.053. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.109, RSMo 1989, amended 1995, 2004, 2008.*

10 CSR 26-2.060 Taking USTs Out of Use

PURPOSE: This rule contains the requirements for underground storage tanks that are taken out of service.

(1) When an underground storage tank (UST) system is out of use, as defined in 10 CSR 26-2.012, the owner and/or operator must continue operation and maintenance of corrosion protection, as described in 10 CSR 26-2.031, and/or interior lining inspection and maintenance, as described in 10 CSR 26-2.021, until the site assessment described in 10 CSR 26-2.062 of this rule has been completed. Release reporting, investigation, and corrective action, as described in 10 CSR 26-2.050–10 CSR 26-2.083, must be performed if a release is suspected or confirmed.

(2) Owners and operators must also comply with the following requirements when a UST system is out of use for three (3) months or more:

(A) Leave vent lines open and functioning; and

(B) Cap and secure all other lines, pumps, manways, and ancillary equipment.

(3) For a UST that remains out of use, within twelve (12) months of taking the UST system out of use, owners and operators must either—

(A) Permanently close the UST system in accordance with 10 CSR 26-2.061–10 CSR 26-2.064; or

(B) Complete a site assessment in accordance with 10 CSR 26-2.062.

(4) Within five (5) years of the date on which the UST was initially taken out of use, the owner or operator must permanently close the UST system, as described in 10 CSR 26-2.061–10 CSR 26-2.064.

(5) To re-open a steel tank system that has been out of use for more than twelve (12) months, the tank owner or operator must—

(A) Complete one (1) of the following three (3) options:

1. Ensure that the steel tank is structurally sound, using an integrity test, as defined in 10 CSR 26-2.021, and—

A. If cathodically protected, the owner or operator must recertify the cathodic protection system in accordance with the requirements described in 10 CSR 26-2.031; or

B. If the tank was internally lined, the owner or operator must ensure that the lining is still functioning as designed and is in compliance with 10 CSR 26-2.021(3)(A);

2. Document that the tank has remained in compliance with the cathodic protection requirements described in 10 CSR 26-2.031; or

3. Document that the tank has remained in compliance with the interior lining requirements described in 10 CSR 26-2.021(3)(A);

(B) Conduct line tightness testing and get a passing result; and

(C) Ensure that all ancillary equipment is tested for proper operation.

(6) To re-open a fiberglass-reinforced plastic tank system that has been out of use for more than twelve (12) months, the tank owner or operator must—

(A) Have the tank and piping recertified by the manufacturer(s); or

(B) Provide tank deflection readings, confirming that these readings are within the manufacturer’s allowable range; and

(C) Conduct line tightness testing and get a passing result; and



(D) Ensure that all ancillary equipment is tested for proper operation.

(7) To re-open a clad steel tank system that has been out of use for more than twelve (12) months, the tank owner or operator must—

(A) Have the tank and piping recertified by the manufacturer(s); or

(B) Conduct line and tank tightness testing and get a passing result; and

(C) Ensure that all ancillary equipment is tested for proper operation.

(8) The department may grant an owner or operator a twelve (12)-month extension to meet the site assessment requirement in section (3) of this rule. The department will consider at least the following criteria when reviewing a request for an extension:

(A) The UST had been in use no more than ten (10) years;

(B) Other USTs remain in use at the site;

(C) The owner or operator demonstrates that his or her financial responsibility mechanism allows additional time in which to report a release from the out-of-use UST and file a claim for that release; and

(D) There is no evidence of a suspected or confirmed release.

(9) Owners and/or operators must notify the department within thirty (30) days of any change in use of the tank (including taking the tank out of use or re-opening the tank).

AUTHORITY: sections 319.105, 319.107 and 319.111, RSMo 2000, and section 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.070. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.105, RSMo 1989; 319.107, RSMo 1989, amended 1994; 319.111, RSMo 1989; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.061 Permanent Closure and Changes in Service

PURPOSE: This rule contains the requirements for permanent closure of underground storage tanks as well as for converting underground storage tanks to an unregulated use.

PUBLISHER'S NOTE: The secretary of state has determined that the publication of the entire text of the material which is incorporated by reference as a portion of this rule would be unduly cumbersome or expensive. This material as incorporated by reference in this rule shall be maintained by the agency at its headquarters and shall be made

available to the public for inspection and copying at no more than the actual cost of reproduction. This note applies only to the reference material. The entire text of the rule is printed here.

(1) Owners and operators must notify the department in writing, on forms provided by the department, at least thirty (30) days before beginning either permanent closure or a change in service of an underground storage tank (UST), unless this action is in response to corrective action or the department approves a shorter time period. The required assessment of the excavation zone under 10 CSR 26-2.062 must be performed after notifying the department but before completion of the permanent closure or a change in service. The closure notice is valid for one hundred eighty (180) days. If permanent closure or change in service does not commence within one hundred eighty (180) days of the date the notice is received by the department, a new closure notice must be submitted prior to commencing closure activities.

(2) To permanently close a tank, owners and operators must empty and clean it by removing all liquids and accumulated sludges. Liquids and sludges shall be managed in accordance with state and federal regulations. All tanks taken out of service permanently must also be either removed from the ground or filled with an inert solid material.

(3) Continued use of a UST system to store a nonregulated substance is a change in service. Before a change in service, owners and operators must empty and clean the tank by removing all liquid and accumulated sludge and conduct a site assessment in accordance with 10 CSR 26-2.062.

(4) Lining a steel tank with a material that is approved as a stand-alone underground storage tank under Underwriters' Laboratories Standard 1316, revised 2006, is a change in service. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the Underwriters' Laboratories, 333 Pfingsten Road, Northbrook, IL 60062-2096, (847) 272-8800, www.ul.com. Before a change in service, owners and operators must empty and clean the tank by removing all liquid and accumulated sludge and conduct a site assessment in accordance with 10 CSR 26-2.062.

(5) Owners and operators shall follow a written procedure. A copy of the written procedure or, if the written procedure is commonly available, a clear reference to the written

procedure shall be submitted to and approved by the department prior to beginning activities required by this rule. It may be supplemented with the following cleaning and closure procedures:

(A) American Petroleum Institute Recommended Practice 1604, *Closure of Underground Petroleum Storage Tanks*, revised 2001. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the American Petroleum Institute, 1220 L Street NW, Washington, DC 20005, (202) 682-8000, www.api.org/standards;

(B) American Petroleum Institute Standard 2015, *Safe Entry and Cleaning of Petroleum Storage Tanks, Planning and Managing Tank Entry from Decommissioning through Recommissioning*, revised 2001. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the American Petroleum Institute, 1220 L Street NW, Washington, DC 20005, (202) 682-8000, www.api.org/standards;

(C) American Petroleum Institute Standard 1631, *Interior Lining and Periodic Inspection of Underground Storage Tanks*, revised 2001. This document is incorporated by reference without any later amendments or modifications. To obtain a copy, contact the American Petroleum Institute, 1220 L Street NW, Washington, DC 20005, (202) 682-8000, www.api.org/standards; and

(D) Owners and operators may use other written procedures with prior written approval of the department.

AUTHORITY: sections 319.105, 319.107, and 319.111, RSMo 2000, and section 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.071. Original rule filed April 2, 1990, effective Sept. 28, 1990. Amended: Filed Aug. 3, 1993, effective April 9, 1994. Amended: Filed April 1, 1999, effective March 30, 2000. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.105, RSMo 1989; 319.107, RSMo 1989, amended 1994; 319.111, RSMo 1989; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.062 Assessing the Site at Closure or Change in Service

PURPOSE: This rule describes the requirements of a site assessment to determine whether there has been a release from the underground storage tank system.

PUBLISHER'S NOTE: The secretary of state has determined that the publication of the



entire text of the material which is incorporated by reference as a portion of this rule would be unduly cumbersome or expensive. This material as incorporated by reference shall be maintained by the agency at its headquarters and shall be made available to the public for inspection and copying at no more than the actual cost of reproduction. This note applies only to the reference material. The entire text of the rule is printed here.

(1) Before permanent closure or a change in service is completed, owners and operators must measure for the presence of a release where contamination is most likely to be present at the underground storage tank (UST) site. In selecting sample types, sample locations, and measurement methods, owners and operators must consider the method of closure, the nature of the stored substance, the type of backfill, the depth to groundwater, and other factors appropriate for identifying the presence of a release.

(2) If contaminated soils, contaminated groundwater, or free product as a liquid or vapor is discovered under section (1) of this rule, or by any other manner, owners and operators must begin site investigation and corrective action in 10 CSR 26-2.070-10 CSR 26-2.083.

(3) Owners and operators shall follow a written procedure.

(A) Until December 31, 2012, owners and operators may use the department's *Risk-Based Corrective Action for Petroleum Storage Tanks* guidance document dated February 2004, as amended March 8, 2005, by *Notice of Modifications to the Process and Interim Guidance Pertaining to Application of the New Soil Type Dependent Tier 1 Risk-Based Target Levels*; the March 18, 2005, *Soil Type Determination Guidelines*; the March 3, 2005, Table 3-1 *Default Target Levels*; the April 2005 Table 4-1 *Soil Concentration Levels to Determine the Need for Groundwater Evaluation During Tank Closure*; the February 2005 Tables 7-1(a) through 7-12(c) *Tier 1 Risk-Based Target Levels*; and the April 21, 2005, *Soil Gas Sampling Protocol*. The guidance and amendments were published by the Department of Natural Resources, PO Box 176, Jefferson City, MO 65102-0176, and are hereby incorporated by reference. This rule does not incorporate any subsequent amendments or additions.

(B) Other written procedures may be used with prior written approval of the department.

AUTHORITY: section 319.111, RSMo 2000, and section 319.137, RSMo Supp. 2010.* This rule originally filed as 10 CSR 20-10.072. Original rule filed April 2, 1990, effective Sept. 28, 1990. Amended: Filed Aug. 3, 1993, effective April 9, 1994. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.

*Original authority: 319.111, RSMo 1989 and 319.137, RSMo 1989, amended 1993, 1995, 2004.

10 CSR 26-2.063 Applicability to Previously Closed Underground Storage Tank Systems

PURPOSE: This rule describes the responsibilities of owners and operators of underground storage tanks closed before December 22, 1988.

(1) The department may require that the owner and operator of an underground storage tank (UST) system permanently closed before December 22, 1988, must assess the excavation zone and close the UST system in accordance with 10 CSR 26-2.060-10 CSR 26-2.064 if releases from the UST, in the judgment of the department, may pose a current or potential threat to human health and the environment.

AUTHORITY: section 319.111, RSMo 2000, and sections 319.109 and 319.137, RSMo Supp. 2010.* This rule originally filed as 10 CSR 20-10.073. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.

*Original authority: 319.109, RSMo 1989, amended 1995, 2004, 2008; 319.111, RSMo 1989; and 319.137, RSMo 1989, amended 1993, 1995, 2004.

10 CSR 26-2.064 Closure Records

PURPOSE: This rule requires the owner and the operator to keep records documenting the closure and site assessment of underground storage tank systems.

(1) Owners and operators must maintain records in accordance with 10 CSR 26-2.034 that are capable of demonstrating compliance with closure requirements in 10 CSR 26-2.060-10 CSR 26-2.064. The results of the site assessment in 10 CSR 26-2.062 must be maintained for at least three (3) years after completion of permanent closure or change in service in one (1) of the following ways:

(A) By the owners and operators who took the underground storage tank (UST) system out of service;

(B) By the current owners and operators of the UST system site; or

(C) By mailing these records to the department if they cannot be maintained at the closed facility.

AUTHORITY: sections 319.107 and 319.111, RSMo 2000, and section 319.137, RSMo Supp. 2010.* This rule originally filed as 10 CSR 20-10.074. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.

*Original authority: 319.107, RSMo 1989, amended 1994; 319.111, RSMo 1989; and 319.137, RSMo 1989, amended 1993, 1995, 2004.

10 CSR 26-2.070 Release Response and Corrective Action

PURPOSE: This rule establishes general procedures for responding to leaks of spills at underground storage tanks.

(1) Owners and operators of petroleum or hazardous substance underground storage tank (UST) systems must comply, in response to a confirmed release from the UST system, with the requirements of 10 CSR 26-2.070-10 CSR 26-2.083 except for USTs excluded under 10 CSR 26-2.010(2) and UST systems subject to the Resource Conservation and Recovery Act (RCRA), Subtitle C corrective action requirements under Section 3004(u).

AUTHORITY: sections 319.109 and 319.137, RSMo Supp. 2010.* This rule originally filed as 10 CSR 20-10.060. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.

*Original authority: 319.109, RSMo 1989, amended 1995, 2004, 2008 and 319.137, RSMo 1989, amended 1993, 1995, 2004.

10 CSR 26-2.071 Initial Release Response and Corrective Action

PURPOSE: This rule describes the immediate steps owners and operators of a leaking underground storage tank must take.

(1) Upon confirmation of a release in 10 CSR 26-2.052, or after a release from the underground storage tank (UST) system is identified in any other manner, owners and operators must perform the following initial response actions within twenty-four (24) hours:

(A) Report the release to the department in accordance with 10 CSR 26-2.050;



(B) Take immediate action to prevent any further release of the regulated substance into the environment; and

(C) Identify and mitigate fire, explosion, and vapor hazards.

*AUTHORITY: section 319.109, RSMo Supp. 2010. * This rule originally filed as 10 CSR 20-10.061. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.109, RSMo 1989, amended 1995, 2004, 2008.*

10 CSR 26-2.072 Initial Abatement Measures and Investigation

PURPOSE: This rule describes the first steps to stop the spread of the release and finding the extent of the release.

(1) Unless directed to do otherwise by the department, owners and operators must perform the following abatement measures upon confirmation of a release:

(A) Remove as much of the regulated substance from the underground storage tank (UST) system as is necessary to prevent further release to the environment;

(B) Visually inspect any above-ground releases or exposed below-ground releases and prevent further migration of the released substance into surrounding soils and groundwater;

(C) Continue to monitor and mitigate any additional fire and safety hazards posed by vapors or free product that have migrated from the UST excavation zone and entered into subsurface structures such as sewers or basements;

(D) Remedy hazards posed by contaminated soils that are excavated or exposed as a result of release confirmation, site investigation, abatement or corrective action activities. If these remedies include treatment or disposal of soils, the owner and operator must comply with applicable state and local requirements;

(E) Measure for the presence of a release where contamination is most likely to be present at the UST site, unless the presence and source of the release have been confirmed in accordance with the site check required by 10 CSR 26-2.052(1)(B) or the closure site assessment of 10 CSR 26-2.062. In selecting sample types, sample locations, and measurement methods, the owner and operator must consider the nature of the stored substance, the type of backfill, depth to groundwater, and other factors as appropriate for identify-

ing the presence and source of the release; and

(F) Investigate to determine the possible presence of free product and begin free product removal as soon as practicable in accordance with 10 CSR 26-2.075.

(2) Within twenty (20) days after release confirmation, owners and operators must submit a report to the department summarizing the initial abatement steps taken under section (1) of this rule and any resulting information.

*AUTHORITY: sections 319.109 and 319.137, RSMo Supp. 2010. * This rule originally filed as 10 CSR 20-10.062. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.109, RSMo 1989, amended 1995, 2004, 2008 and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.074 Initial Site Characterization

PURPOSE: This rule describes the steps for investigation of a release.

(1) Unless directed to do otherwise by the department, owners and operators must assemble information about the site and the nature of the release, including information gained while confirming the release or completing the initial abatement measures in 10 CSR 26-2.070, 10 CSR 26-2.071, and 10 CSR 26-2.072. This information must include, but is not necessarily limited to, the following:

(A) Data on the nature and estimated quantity of release;

(B) Data from available sources or site investigations concerning the following factors: surrounding populations, water quality, use and approximate locations of wells potentially affected by the release, subsurface soil conditions, locations of subsurface sewers, climatological conditions, and land use;

(C) Results of the site check required under 10 CSR 26-2.072(1)(E); and

(D) Results of the free product investigations required under 10 CSR 26-2.072(1)(F) to be used by owners and operators to determine whether free product must be recovered under 10 CSR 26-2.075.

(2) Within forty-five (45) days of release confirmation, owners and operators must submit the information collected in compliance with section (1) of this rule to the department or in a format and according to the schedule required by the department.

*AUTHORITY: sections 319.109 and 319.137, RSMo Supp. 2010. * This rule originally filed as 10 CSR 20-10.063. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.109, RSMo 1989, amended 1995, 2004, 2008 and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.075 Free-Product Removal

PURPOSE: This rule requires spilled, free product to be collected immediately.

(1) At sites where the investigation reveals free product under 10 CSR 26-2.072(1)(F), owners and operators must remove as much free product as practicable as determined by the department. Any actions initiated under 10 CSR 26-2.071–10 CSR 26-2.074 or preparation for actions required under 10 CSR 26-2.078–10 CSR 26-2.082 must also be continued. In meeting the requirements of this rule, owners and operators must—

(A) Remove free product to minimize the spread of contamination into previously uncontaminated zones. The recovery and disposal techniques must be appropriate to the hydrogeologic conditions at the site. Recovered by-products must be treated, discharged or disposed in compliance with applicable local, state and federal regulations;

(B) Use abatement of free-product migration as a minimum objective for free product removal;

(C) Handle any flammable products in a safe and competent manner to prevent fires or explosions; and

(D) Prepare and submit to the department a free-product removal report, within forty-five (45) days after confirming a release, unless otherwise directed by the department. The report shall provide at least the following information:

1. The name of the person(s) responsible for implementing the free product removal measures;

2. The estimated quantity, type and thickness of free product observed or measured in wells, boreholes, and excavations;

3. The type of free-product recovery system used;

4. Whether any discharge will take place on-site or off-site during the recovery operation and the location of this discharge;

5. The type of treatment applied to, and the effluent quality expected from, any discharge;



6. The steps that have been or are being taken to obtain necessary permits for any discharge; and

7. The disposition of the recovered free product.

AUTHORITY: sections 319.109 and 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.064. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.109, RSMo 1989, amended 1995, 2004, 2008 and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.078 Investigations for Soil and Groundwater Cleanup

PURPOSE: This rule describes the procedures for soil and groundwater investigations.

PUBLISHER'S NOTE: The secretary of state has determined that the publication of the entire text of the material which is incorporated by reference as a portion of this rule would be unduly cumbersome or expensive. This material as incorporated by reference in this rule shall be maintained by the agency at its headquarters and shall be made available to the public for inspection and copying at no more than the actual cost of reproduction. This note applies only to the reference material. The entire text of the rule is printed here.

(1) Owners and operators must conduct investigations of the release, the release site, and the surrounding area to determine the full extent and location of soils contaminated by the release and the presence and concentrations of dissolved product contamination in the groundwater if any of the following conditions exist:

(A) There is evidence that groundwater wells have been affected by the release (for example, as found during release confirmation or previous corrective action measures);

(B) Free product is found to need recovery in compliance with 10 CSR 26-2.075;

(C) There is evidence that contaminated soils may be in contact with groundwater as found during the initial response measures or investigations required under 10 CSR 26-2.070–10 CSR 26-2.075; or

(D) The department requests an investigation based on the potential effects of contaminated soil or groundwater on nearby surface and groundwater resources.

(2) Owners and operators must submit the

information collected under section (1) of this rule as soon as practicable or in accordance with a schedule established by the department.

(3) Owners and operators shall follow a written procedure.

(A) Until December 31, 2012, owners and operators may use the department's *Risk-Based Corrective Action for Petroleum Storage Tanks* guidance document dated February 2004, as amended March 8, 2005, by *Notice of Modifications to the Process and Interim Guidance Pertaining to Application of the New Soil Type Dependent Tier 1 Risk-Based Target Levels*; the March 18, 2005, *Soil Type Determination Guidelines*; the March 3, 2005, Table 3-1 *Default Target Levels*; the April 2005 Table 4-1 *Soil Concentration Levels to Determine the Need for Groundwater Evaluation During Tank Closure*; the February 2005 Tables 7-1(a) through 7-12(c) *Tier 1 Risk-Based Target Levels*; and the April 21, 2005, *Soil Gas Sampling Protocol*. The guidance and amendments were published by the Department of Natural Resources, PO Box 176, Jefferson City, MO 65102-0176, and are hereby incorporated by reference. This rule does not incorporate any subsequent amendments or additions.

(B) Other written procedures may be used with prior written approval of the department.

AUTHORITY: sections 319.109 and 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.065. Original rule filed April 2, 1990, effective Sept. 28, 1990. Amended: Filed Aug. 3, 1993, effective April 9, 1994. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.109, RSMo 1989, amended 1995, 2004, 2008 and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.080 Risk-Based Target Levels

PURPOSE: This rule sets clean-up levels for underground storage tank corrective actions and for site assessment, site characterization, and workplan development, which are all stages in developing clean-up levels. The rule also sets deed notice language to assure that the site is not used in a manner which would pose unacceptable risk or exposure. The rule requires that sites be ranked and that the ranking be used to allocate staff and funds.

(1) Applicability. This rule applies to all cleanups of petroleum releases from underground storage tanks (USTs).

(2) Upon being so directed by the department, the UST remediator shall conduct a preliminary assessment of the site.

(A) The requirement for a preliminary assessment is waived if permanent closure is being conducted, or significant contamination is known to exist at the site, and the department has been notified of a release as required in 10 CSR 24-3.010(1).

(B) The preliminary assessment shall be conducted according to department guidance.

(3) The department will evaluate the results of the preliminary assessment to rank the site relative to other sites for further characterization and/or corrective action.

(A) If the preliminary assessment shows contamination levels below the action levels outlined in the department's underground storage tank closure guidance document, the department will require no further action at the site.

(B) If, in accordance with subsection (3)(A) of this rule, the department determines that no further action is required at a site, and if subsequent information becomes available to indicate that contamination may be present at the site at levels which may threaten human health or the environment, the department may require additional investigation or site characterization and/or corrective action.

(4) If full site characterization is required by the department, due to known contamination or in accordance with subsection (3)(B) of this rule, the UST remediator shall conduct the site characterization according to department guidance.

(5) The department will review the site characterization and rank the site relative to other sites based on site conditions as reflected in the site characterization and the potential risk to human health and/or the environment.

(A) The rank assigned to the site will be used to prioritize department actions including, but not limited to review of documents, pre-approval of costs and reimbursement of costs, in regard to the site.

(B) The department will not require further action at sites that the department deems not to pose a risk to human health and/or the environment, unless there is a change in known conditions at the site that would upgrade its priority, as determined by the department.

(6) Except as provided in section (8) of this rule, site clean-up objectives will be set as follows:

(A) Site clean-up objectives for the cleanup of petroleum released from underground storage tanks will be set by using the scoring



matrix and the groundwater clean-up standards as outlined in the department's underground storage tank closure guidance document.

(B) *(Reserved)* (Note: The soil scoring matrix is a site-specific risk-based method which accounts for future land use and other considerations. Upon further development and review, this method or another which also meets statutory requirements, will be set forth in this section.)

(7) Site clean-up objectives and workplans are subject to approval by the department. Such approval must be granted in writing prior to implementation of the workplan.

(8) For all sites which are cleaned up to meet levels less stringent than (higher than) those set according to section (6) of this rule, the UST remediator shall file a document in the chain of title of the property. The document shall state that the contaminant levels were deemed acceptable by the department, based on the land use and other considerations, at the time of cleanup.

(A) If the UST remediator is a person other than the landowner, the UST remediator shall provide a copy of the document which is to be filed in the chain of title for the property, by certified mail to the landowner.

(B) The language of the document to be filed in the chain of title shall include the following:

NOTICE OF ACCEPTABLE LAND
USE(S) OF UNDERGROUND STORAGE
TANK SITE

Owner of Record: *(Landowner's Name)*

Site Description: *(Site Name and Legal Description)*

The above-described real property, owned by *(Landowner's Name)* and located in the County of *(County Name)* and State of Missouri, is the site of an underground storage tank which was *(Removed/Closed)* on *(Date)*. The site cleanup was accepted as complete by the Missouri Department of Natural Resources on *(Date)*, in accordance with the applicable requirements of Title 10, Division 25, Chapters 10 through 12 of the *Code of State Regulations* which were in effect at the time of cleanup. The contaminant levels remaining on the site are suitable for *(Commercial/Light Industrial/Heavy Industrial/ Other Specified)* use.

In witness whereof I hereunto set my hand this ____ day of ___, 19__.

(Office)

(Name)

(Title)

(C) No person may substantially change the manner in which a site with a document filed in the chain of title under this section is used without the prior written approval of the director or the director's designee.

1. Requests for approval of change in use of real property must be submitted in writing to the director's office no less than sixty (60) days prior to the planned change in use of real property. In the event the director does not respond within sixty (60) days after the request is received, the request will be considered to be approved as submitted.

2. The director will evaluate the request to determine whether the change in use of real property is likely to result in increased exposure of persons or the environment or spread of contamination.

3. If the change in use of real property is not likely to result in increased exposure of persons or the environment or spread of contamination, the director shall provide written approval.

(D) When the director finds that a site which has had a document filed in the chain of title under this section has been further cleaned up to meet or exceed (lower levels than) the standards described in section (6) of this rule, the director shall direct the UST remediator to file a second document in the chain of title. The document shall include the language in subsection (8)(B) of this rule, and shall describe the land uses for which the new contaminant levels are suitable.

AUTHORITY: section 319.111, RSMo 2000, and sections 319.109 and 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.068. Original rule filed Jan. 2, 1996, effective Aug. 30, 1996. Amended: Filed Jan. 14, 1997, effective Sept. 30, 1997. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.109, RSMo 1989, amended 1995, 2004, 2008; 319.111, RSMo 1989; and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.082 Corrective Action Plan

PURPOSE: This rule lists the requirements for corrective action plans for cleanup of releases from underground storage tank sites.

PUBLISHER'S NOTE: The secretary of state has determined that the publication of the

entire text of the material which is incorporated by reference as a portion of this rule would be unduly cumbersome or expensive. This material as incorporated by reference in this rule shall be maintained by the agency at its headquarters and shall be made available to the public for inspection and copying at no more than the actual cost of reproduction. This note applies only to the reference material. The entire text of the rule is printed here.

(1) Owners and operators are responsible for submitting a plan that provides for adequate protection of human health and the environment, as determined by the department, after fulfilling the requirements for release reporting and investigation in 10 CSR 26-2.071–10 CSR 26-2.074. Owners and operators must modify their plan as necessary to meet this standard.

(A) The department may require owners and operators to submit additional information or to develop and submit a corrective action plan for responding to contaminated soils and groundwater at any point after reviewing the information submitted for release reporting and investigation in 10 CSR 26-2.071–10 CSR 26-2.074. If a plan is required, owners and operators must submit the plan according to a schedule and format established by the department.

(B) Owners and operators may choose to submit a corrective action plan for responding to contaminated soil and groundwater after fulfilling the requirements of 10 CSR 26-2.071–10 CSR 26-2.074.

(2) The department will approve the corrective action plan only after ensuring that implementation of the plan will adequately protect human health and safety and the environment. In making this determination the department should consider the following factors as appropriate:

(A) The physical and chemical characteristics of the regulated substance, including its toxicity, persistence and potential for migration;

(B) The hydrogeologic characteristics of the facility and the surrounding area;

(C) The proximity, quality, and current and future uses of nearby surface and ground water;

(D) The potential effects of residual contamination on nearby surface and ground water;

(E) An exposure assessment; and

(F) Any information assembled in 10 CSR 26-2.070–10 CSR 26-2.083.



(3) Upon approval of the corrective action plan, or as directed by the department, owners and operators must implement the plan including modifications to the plan made by the department. Owners and operators must monitor, evaluate and report the results of implementing the plan in accordance with a schedule and in a format established by the department.

(4) Owners and operators, in the interest of minimizing environmental contamination and promoting more effective clean-up, may begin clean-up of soil and groundwater before the corrective action plan is approved provided that they—

(A) Notify the department of their intention to begin clean-up;

(B) Comply with any conditions imposed by the department, including halting clean-up or mitigating adverse consequences from clean-up activities; and

(C) Incorporate these self-initiated clean-up measures in the corrective action plan that is submitted to the department for approval.

(5) Owners and operators shall follow a written procedure.

(A) Until December 31, 2012, owners and operators may use the department's *Risk-Based Corrective Action for Petroleum Storage Tanks* guidance document dated February 2004, as amended March 8, 2005, by *Notice of Modifications to the Process and Interim Guidance Pertaining to Application of the New Soil Type Dependent Tier 1 Risk-Based Target Levels*; the March 18, 2005, *Soil Type Determination Guidelines*; the March 3, 2005, Table 3-1 *Default Target Levels*; the April 2005 Table 4-1 *Soil Concentration Levels to Determine the Need for Groundwater Evaluation During Tank Closure*; the February 2005 Tables 7-1(a) through 7-12(c) *Tier 1 Risk-Based Target Levels*; and the April 21, 2005, *Soil Gas Sampling Protocol*. The guidance and amendments were published by the Department of Natural Resources, PO Box 176, Jefferson City, MO 65102-0176, and are hereby incorporated by reference. This rule does not incorporate any subsequent amendments or additions.

(B) Other written procedures may be used with prior written approval of the department.

AUTHORITY: sections 319.109 and 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.066. Original rule filed April 2, 1990, effective Sept. 28, 1990. Amended: Filed Aug. 3, 1993, effective April 9, 1994. Moved and amended: Filed April*

15, 2011, effective Dec. 30, 2011.

**Original authority: 319.109, RSMo 1989, amended 1995, 2004, 2008 and 319.137, RSMo 1989, amended 1993, 1995, 2004.*

10 CSR 26-2.083 Public Participation

PURPOSE: This rule establishes procedures for public participation during corrective action plans.

(1) For each confirmed release that requires a corrective action plan, the department must provide notice to the public by means designed to reach those members of the public directly affected by the release and the planned corrective action. This notice may include, but is not limited to, public notice in local newspapers, block advertisements, public service announcements, publication in a state register, letters to individual households or personal contacts by field staff.

(2) Site release information and decisions by the department concerning the corrective action plan are available to the public for inspection upon request.

(3) Before approving any corrective action plan, the department may hold a public meeting to consider comments on the proposed corrective action plan if there is sufficient public interest or for any other reason.

(4) The department must give public notice in section (1) of this rule if implementation of an approved corrective action plan does not achieve the established clean-up levels in the plan and termination of that plan is under consideration by the department.

AUTHORITY: sections 319.109 and 319.137, RSMo Supp. 2010. This rule originally filed as 10 CSR 20-10.067. Original rule filed April 2, 1990, effective Sept. 28, 1990. Moved and amended: Filed April 15, 2011, effective Dec. 30, 2011.*

**Original authority: 319.109, RSMo 1989, amended 1995, 2004, 2008 and 319.137, RSMo 1989, amended 1993, 1995, 2004.*